NOTICE TO WATER WELL CONTRACTOR
The original and first control of this report are to be filed with the JUN 3 0 1971 STATE OF OREGON
STATE ENGINEER, SALEM, OREGON 97310 within 30 days from the later ATE ENGINEER type or print)
of well completion.

140001	 
State Well No. 2 2W-25	
State Permif No.	

of well completion. SALEM. OF The not write in	Sove this line)	-	·
1) OWNER:	(10) LOCATION OF WELL:		
Name Roger Berryhill	County Washington Driller's well no	ımber	<u> </u>
Address Route 4, Box 304	34 14 Section 23 T. 2 S	R.	2 W. w.м.
Sherwood, Oregon	Bearing and distance from section or subdivisi		
2) TYPE OF WORK (check):		-	
New Well ☑ Deepening □ Reconditioning □ Abandon □			
f abandonment, describe material and procedure in Item 12.	(11) WATER LEVEL: Completed w	ell.	
3) TYPE OF WELL: (4) PROPOSED USE (check):	Depth at which water was first found	65	ft.
totary M Driven Domestic Dindustrial Municipal Domestic	Static level 21 ft. below land s	surface. Date	6/28/71
Table   Jetted	Artesian pressure Ibs. per squar	9 4	
CASING INSTALLED: Threaded □ Welded ☑	(12) WELL LOG: Diameter of well l	nologo f	811
8 "Diam from 9 ft to 11 ft Gage 250	2/2	_	250
tt. toft. Gage			
" Diam. from ft. to ft. Gage	Formation: Describe color, texture, grain size and show thickness and nature of each stratus		
DEDUCTOR A MYONIC	with at least one entry for each change of forma	tion. Report ed	ich change in
PERFORATIONS: Perforated? ☐ Yes ☑ No.	position of Static Water Level and indicate prin	1	<del></del> ·
Type of perforator used	Top soil	From T	o SWL
Size of perforations in. by in.	Brown clay		16
perforations from	Yellow clay		28
perforations fromft. toft.	Brown clay	1	<u> </u>
perforations fromft. toft.	Brown & gray rock	41	57
7) SCREENS: Well screen installed?   Yes  No	Hard gray rock	57	65
Manufacturer's Name	Brown&Gray-decomposed streaks	65	71 2 gpm
Type Model No	Reddish brown rock	71	87
Diam, Slot size Set from ft. to ft.	Brown & gray rock		.09
Diam Slot size Set from ft. to ft.	Decomposed & Brown&Gray rock		17 20 gpr
(8) WELL TESTS: Drawdown is amount water level is	Brown & gray rock	<u> </u>	41
lowered below static level	Hard gray rock	<del>                                     </del>	.77
Was a pump test made? 🗌 Yes 🔟 No If yes, by whom?	Brown&Gray-decomposed streaks		96 50 gpr
Yield: gal./min. with ft. drawdown after hrs.	Brown & gray rock		209 238
n n	Hard gray rock		250 260 178 gr
n n n	Soft brown & gray perforated	450   4	TIO RI
airlift Baller test 250 gal./min. with 229 ft. drawdown after 2 hrs.			
Artesian flow g.p.m.			
imperature of water Depth artesian flow encounteredft.	Work started 6/22/71 19 Complet	ed 6/28	3/71 19
(0) CONSTIDUCTION.	Date well drilling machine moved off of well	6/28/73	
(9) CONSTRUCTION: Well seel Weterful used Cement	Drilling Machine Operator's Certification:		
Well ocalMatchat uscu	This well was constructed under my	direct su	pervision.
Well sealed from land surface toft.	Materials used and information reported	above are	true to my
Diameter of well bore to bottom of seal $\frac{12}{8}$ in.	best knowledge and belief.  Isigned to him humankank	Date 6/2	28/77.
	[Signed] (Orilling Machine Operator)		
Number of sacks of cement used in well sealsacks Number of sacks of bentonite used in well sealsacks	Drilling Machine Operator's License No.	235	
Brand name of bentonite			
Number of pounds of bentonite per 100 gallons	Water Well Contractor's Certification:		_
of water Ibs./100 gals.	This well was drilled under my jurisd true to the best of my knowledge and be		nis report is
Was a drive shoe used?   Yes No Plugs Size: location ft.	true to the best of my knowledge and be Name A. M. Jannsen Drilling C		
Did any strata contain unusable water? 🗌 Yes 🔣 No	(Person, firm or corporation)	(Type o	r print)
Type of water? depth of strata	Address 21075 8.W. Tualatin Val	ley Hwy,	Aloha, Or
Method of sealing strata off		Municipal	10.
Was well gravel packed? ☐ Yes M No Size of gravel:	[Signed] (Water Well cont		**************************************
Gravel placed from ft. to ft.	Contractor's License No Date	6/28/71	, 19