

NOTICE TO WATER WELL CONTRACTOR

The original and first copy of this report are to be filed with the

STATE ENGINEER, SALEM, OREGON 97300 within 30 days from the date of well completion.

WASH 013072

WATER WELL REPORT FEB 21 1973

STATE OF OREGON STATE ENGINEER SALEM, OREGON

25/2W-26 bd

(Do not write above this line)

(1) OWNER:

Name OREGON WASH. LUMBER CO. Address 301 N.W. MURRAY ROAD PORTLAND ORE.

(2) TYPE OF WORK (check):

New Well [X] Deepening [ ] Reconditioning [ ] Abandon [ ] If abandonment, describe material and procedure in Item 12.

(3) TYPE OF WELL:

Rotary [X] Cable [ ] Driven [ ] Jetted [ ] Bored [ ]

(4) PROPOSED USE (check):

Domestic [X] Industrial [ ] Municipal [ ] Irrigation [ ] Test Well [ ] Other [ ]

(5) CASING INSTALLED:

6" Diam. from +1 ft. to 110 ft. Gage 250 Threaded [ ] Welded [X]

(6) PERFORATIONS:

Type of perforator used TORCH Perforated? [X] Yes [ ] No. Size of perforations 1/8 in. by 6 in. 88 perforations from 79 ft. to 101 ft.

(7) SCREENS:

Well screen installed? [ ] Yes [X] No Manufacturer's Name Type Model No. Diam. Slot size Set from ft. to ft.

(8) WELL TESTS:

Drawdown is amount water level is lowered below static level Was a pump test made? [ ] Yes [X] No If yes, by whom? Bailer test 30 gal./min. with 20 ft. drawdown after 1 hrs.

(9) CONSTRUCTION:

Well seal—Material used CEMENT GROUT Well sealed from land surface to 30 ft. Diameter of well bore to bottom of seal 10 in. Diameter of well bore below seal 6 in. Number of sacks of cement used in well seal 12 sacks

(10) LOCATION OF WELL:

County WASH. Driller's well number 5431 SE 1/4 NW 1/4 Section 26 T. 2S R. 2W W.M. Bearing and distance from section or subdivision corner

(11) WATER LEVEL: Completed well.

Depth at which water was first found 77 ft. Static level 47 ft. below land surface. Date 1/6/73 Artesian pressure lbs. per square inch. Date

(12) WELL LOG:

Diameter of well below casing 6 Depth drilled 110 ft. Depth of completed well 110 ft. Formation: Describe color, texture, grain size and structure of materials; and show thickness and nature of each stratum and aquifer penetrated, with at least one entry for each change of formation.

Table with columns: MATERIAL, From, To, SWL. Rows include TOP SOIL, RED CLAY, BROWN CLAY, BROWN CLAY AND BOULDERS, BROKEN BROWN BASALT, MED. HARD GREY BASALT.

Work started FEB 5 1973 Completed FEB 7 1973 Date well drilling machine moved off of well FEB 7 1973

Drilling Machine Operator's Certification:

This well was constructed under my direct supervision. Materials used and information reported above are true to my best knowledge and belief. [Signed] Ekward J. Schulz Date FEB 9, 1973 Drilling Machine Operator's License No. 564

Water Well Contractor's Certification:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Name R.J. STRASSER DRILLING Co. Address 8110 SE SUNSET LANE PORTLAND ORE. [Signed] Robert L. Strasser Date FEB 9, 1973 Contractor's License No. 10