

NOTICE TO WATER WELL CONTRACTOR  
The original and first copy  
of this report are to be  
filed with the

STATE ENGINEER, SALEM, OREGON 97310  
within 30 days from the date  
of well completion.

WASH WATER WELL REPORT RECEIVED

STATE OF OREGON SEP 24 1974

State Well No. 25/2W-29

(Please type or print)

STATE ENGINEER  
SALEM, OREGON

State Permit No.

013132

(Do not write above this line)

(1) OWNER:

Name Jack and Sue Peterson  
Address 9560 S. W. Clark Hill Road Beaverton Oregon 97008

(2) TYPE OF WORK (check):

New Well  Deepening  Reconditioning  Abandon

If abandonment, describe material and procedure in Item 12.

(3) TYPE OF WELL:

Rotary  Driven   
Cable  Jetted   
Dug  Bored

(4) PROPOSED USE (check):

Domestic  Industrial  Municipal   
Irrigation  Test Well  Other

CASING INSTALLED:

6" Diam. from 0 ft. to 103 ft. Gage 250  
" Diam. from ft. to ft. Gage  
" Diam. from ft. to ft. Gage

PERFORATIONS:

Perforated?  Yes  No.

Type of perforator used

Size of perforations in. by in.  
perforations from ft. to ft.  
perforations from ft. to ft.  
perforations from ft. to ft.

(7) SCREENS:

Well screen installed?  Yes  No

Manufacturer's Name  
Type Model No.  
Diam. Slot size Set from ft. to ft.  
Diam. Slot size Set from ft. to ft.

(8) WELL TESTS:

Drawdown is amount water level is lowered below static level

Was a pump test made?  Yes  No If yes, by whom?  
Yield: gal./min. with ft. drawdown after hrs.  
" " " "  
" " " "  
" " " "  
Packer test 12 gal./min. with 40 ft. drawdown after 1 hrs.  
Artesian flow g.p.m.  
Temperature of water Depth artesian flow encountered ft.

(9) CONSTRUCTION:

Well seal—Material used Cement  
Well sealed from land surface to 103 ft.  
Diameter of well bore to bottom of seal 9 in.  
Diameter of well bore below seal 6 in.  
Number of sacks of cement used in well seal 10 sacks  
Number of sacks of bentonite used in well seal sacks  
Brand name of bentonite  
Number of pounds of bentonite per 100 gallons of water lbs./100 gals.  
Was a drive shoe used?  Yes  No Plugs Size: location ft.  
Did any strata contain unusable water?  Yes  No  
Type of water? depth of strata  
Method of sealing strata off  
Was well gravel packed?  Yes  No Size of gravel: ft.  
Gravel placed from ft. to ft.

(10) LOCATION OF WELL:

County Washington Driller's well number  
1/4 1/4 Section 29 T. 2-S R. 2-W W.M.  
Bearing and distance from section or subdivision corner

(11) WATER LEVEL: Completed well.

Depth at which water was first found 76 trace ft.  
Static level 200 ft. below land surface. Date 9-16-74  
Artesian pressure lbs. per square inch. Date

(12) WELL LOG:

Diameter of well below casing 6  
Depth drilled 260 ft. Depth of completed well 260 ft.  
Formation: Describe color, texture, grain size and structure of materials; and show thickness and nature of each stratum and aquifer penetrated, with at least one entry for each change of formation. Report each change in position of Static Water Level and indicate principal water-bearing strata.

MATERIAL	From	To	SWL
Top soil	0	3	
Brown clay	3	9	
Red clay	9	28	
Brown clay	28	76	
Brown sandstone	76	94	
Blue med. rock	94	148	
Blue lava rock	148	154	
Blue med. rock	154	203	
Brown lava rock	203	211	
<del>Blue med. rock</del> med. rock blue	211	228	
Brown lava rock	228	239	
Black med. rock	239	260	

Work started 9-16-74 19 Completed 9-17-74 19  
Date well drilling machine moved off of well 9-17-74 19

Drilling Machine Operator's Certification:

This well was constructed under my direct supervision. Materials used and information reported above are true to my best knowledge and belief.

[Signed] *Ralph Turner* Date 9-19-74  
(Drilling Machine Operator)

Drilling Machine Operator's License No. 254

Water Well Contractor's Certification:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

Name Ralph Turner Drilling Co. (Type or print)  
(Person, firm or corporation)

Address Rte 1 Box 141 Hillsboro, Oregon

[Signed] *Ralph Turner*  
(Water Well Contractor)

Contractor's License No. 247 Date 9-19-74 19