

**NOTICE TO WATER WELL CONTRACTOR**

The original and file copy of this report are to be filed with the

**RECEIVED**  
**JUN 24 1969**  
**STATE ENGINEER**  
**SALEM, OREGON**

**WATER WELL REPORT**

STATE OF OREGON

STATE ENGINEER, SALEM, OREGON 97310

within 30 days from the date of well completion. (Please type or print) (Do not write above this line)

State Well No. 2/2W-25

State Permit No. G-63632G-7098

G5645

36 aa

**(1) OWNER:**

Name James & Mitsuko Hasuike  
 Address 15265 S.W. BEND RD., TIGARD, OREGON

**(2) TYPE OF WORK (check):**

New Well  Deepening  Reconditioning  Abandon

If abandonment, describe material and procedure in Item 12.

**(3) TYPE OF WELL:**

Rotary  Driven   
 Cable  Jetted   
 Dug  Bored

**(4) PROPOSED USE (check):**

Domestic  Industrial  Municipal   
 Irrigation  Test Well  Other

**CASING INSTALLED:**

12" Diam. from 0 ft. to 108 ft. Gage #330  
 " Diam. from ft. to ft. Gage  
 " Diam. from ft. to ft. Gage

**PERFORATIONS:**

Perforated?  Yes  No.

Type of perforator used

Size of perforations in. by in.  
 perforations from ft. to ft.  
 perforations from ft. to ft.  
 perforations from ft. to ft.  
 perforations from ft. to ft.

**(7) SCREENS:**

Well screen installed?  Yes  No

Manufacturer's Name  
 Type Model No.  
 Diam. Slot size Set from ft. to ft.  
 Diam. Slot size Set from ft. to ft.

**(8) WATER LEVEL: Completed well.**

Static level 135 ft. below land surface Date 6/5/69  
 Artesian pressure lbs. per square inch Date

**(9) WELL TESTS:**

Drawdown is amount water level is lowered below static level HAAKON

Was a pump test made?  Yes  No If yes, by whom? BOTTNER  
 Yield: 252 gal./min. with 27 ft. drawdown after 2 hrs.  
401 " " 31 1/2 " " 2 "  
733 " " 62 " " 6 "

Baller test gal./min. with ft. drawdown after hrs.

Artesian flow g.p.m. Date

Temperature of water 55 Was a chemical analysis made?  Yes  No

**(10) CONSTRUCTION:**

Well seal—Material used Cement, Sand & Bentonite  
 Depth of seal 52' & 35' ft.  
 Diameter of well bore to bottom of seal 16 in.  
 Were any loose strata cemented off?  Yes  No Depth  
 Was a drive shoe used?  Yes  No  
 Did any strata contain unusable water?  Yes  No  
 Type of water? depth of strata  
 Method of sealing strata off  
 Was well gravel packed?  Yes  No Size of gravel:  
 Gravel placed from ft. to ft.

**(11) LOCATION OF WELL:**

County Washington Driller's well number  
 1/4 1/4 Section 25 T. 2S. R. 2W. W.M.  
 Bearing and distance from section or subdivision corner

**(12) WELL LOG:**

Diameter of well below casing 12"

Depth drilled 585 ft. Depth of completed well 585 ft.

Formation: Describe color, texture, grain size and structure of materials; and show thickness and nature of each stratum and aquifer penetrated, with at least one entry for each change of formation. Report each change in position of Static Water Level as drilling proceeds. Note drilling rates.

MATERIAL	From	To	SWL
Top soil	0	2	
Clay, brown	2	21	
Clay, red, sandy	21	39	
Sandrock, yellow	39	58	
Gravel & Boulders, W. brng.	58	62	38
Boulders, large	62	76	
Clay, brown	76	88	
Clay, gray	88	101	
Rock, brown soft	101	110	
Rock, gray mdm.	110	174	
Rock, black soft	174	198	
Rock, gray hard	198	230	
Rock, black hard	230	276	
Rock, black soft W. brng.	276	284	
Rock, brown soft	284	289	
Rock, black hard	289	311	
Rock, red soft W. brng	311	316	145
Rock, black hard	316	332	
Rock, black w/ seams of black clay	332	338	
Rock, black	338	354	
Clay, blue	354	356	

Work started 19 Completed 19

Date well drilling machine moved off of well 19

Drilling Machine Operator's Certification: See additional sheet

This well was constructed under my direct supervision. Materials used and information reported above are true to my best knowledge and belief.

[Signed] Haakon Bottner Date 6/30/69, 1969  
 (Drilling Machine Operator)

Drilling Machine Operator's License No. 431

**Water Well Contractor's Certification:**

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

NAME HAAKON BOTTNER DRILLING COMPANY  
 (Person, firm or corporation) (Type or print)

Address 3424 S.E. 174 th. AVE. PORTLAND, ORE.

[Signed] Haakon Bottner  
 (Water Well Contractor)

Contractor's License No. 109 Date 6/20/69, 1969

