

RECEIVED

WASH 013306

28/22/100 1442

NOV - 4 1988

STATE OF OREGON WATER WELL REPORT (as required by ORS 537.765)

WATER RESOURCES DEPT. (9) LOCATION OF WELL by legal description: COUNTY Washington

(1) OWNER: Name Egger Enterprises, Address Route 2, Box 362, Hillsboro, Oregon 97123

Latitude, Longitude, Township 2S, Range 3 W, Section 1 SW 1/4 NE 1/4

(2) TYPE OF WORK: [X] New Well, [ ] Deepen, [ ] Recondition, [ ] Abandon

(10) STATIC WATER LEVEL: 25 ft. below land surface, Date 11/1/88

(3) DRILL METHOD: [X] Rotary Air, [X] Rotary Mud, [ ] Cable, [ ] Other

(11) WATER BEARING ZONES: 231

(4) PROPOSED USE: [ ] Domestic, [ ] Community, [ ] Industrial, [X] Irrigation

(5) BORE HOLE CONSTRUCTION: Special Construction approval Yes No, Depth of Completed Well 518 ft.

Table with 4 columns: From, To, Estimated Flow Rate, SWL. Rows include 231-255 (50 gpm), 267-300 (100 gpm), 326-360 (150 gpm), 473-518 (200 gpm).

Table with 6 columns: HOLE Diameter, SEAL Material, Amount. Rows include 14" to 180" Cement/gel (12 sacks), 10" to 518" Cement-gel (10 sacks).

(12) WELL LOG: Ground elevation 180ft. Table with 4 columns: Material, From, To, SWL. Lists various geological layers like Brown clay, Blue-gray clay, etc.

How was seal placed: Method [X] A, [ ] B, [X] C, [ ] D, [ ] E. Backfill placed from 40 ft. to 140 ft. Material Hivisc. gel.

(6) CASING/LINER: Table with 8 columns: Diameter, From, To, Gauge, Steel, Plastic, Welded, Threaded. Shows casing 10" to 180" with 250 gauge.

Final location of shoe(s)

(7) PERFORATIONS/SCREENS: Table with 8 columns: From, To, Slot size, Number, Diameter, Tele/pipe size, Casing, Liner.

(8) WELL TESTS: Minimum testing time is 1 hour. Table with 4 columns: Yield gal/min, Drawdown, Drill stem at, Time. Shows 400 gal/min at 60" drawdown for 1 hr.

Date started 10/5/88, Completed 11/2/88. (unbonded) Water Well Constructor Certification: I certify that the work I performed...

Temperature of water 58° F, Depth Artesian Flow Found. Was a water analysis done? [ ] Yes. Did any strata contain water not suitable for intended use? [ ] Top little.

(bonded) Water Well Constructor Certification: I accept responsibility for the construction, alteration, or abandonment work performed on this well...