

File Original and First Copy with the STATE ENGINEER, SALEM, OREGON

RECEIVED NOV 6 1961 STATE ENGINEER

WATER WELL REPORT STATE OF OREGON

WASH 013318

State Well No. 2/3W-1ad

State Permit No. 8-6462

(1) OWNER: SALEM, OREGON Name Sam E. Stoller Address Rt 2 Bx 56 Hillsboro, Oregon

(2) LOCATION OF WELL: County Wash Owner's number, if any - 1/4 Section T. R. W.M. Bearing and distance from section or subdivision corner

Sec. 1 T2S R3W

(3) TYPE OF WORK (check): Well [X] Deepening [ ] Reconditioning [ ] Abandon [ ]

(4) PROPOSED USE (check): Domestic [X] Industrial [ ] Municipal [ ] Irrigation [X] Test Well [ ] Other [ ] (5) TYPE OF WELL: Rotary [ ] Driven [ ] Cable [X] Jetted [ ] Dug [ ] Bored [ ]

(6) CASING INSTALLED: Threaded [ ] Welded [X] 6" Diam. from -1 ft. to 272' 11" ft. Gage std Cast Steel Drive Shaft

(7) PERFORATIONS: Perforated? [ ] Yes [X] No Type of perforator used SIZE of perforations in. by in. perforations from ft. to ft.

(8) SCREENS: Well screen installed [ ] Yes [X] No Manufacturer's Name Model No. Slot size Set from ft. to ft. Diam. Slot size Set from ft. to ft.

(9) CONSTRUCTION: Was well gravel packed? [ ] Yes [X] No Size of gravel: Gravel placed from ft. to ft. Was a surface seal provided? [X] Yes [ ] No To what depth? ? ft. Material used in seal - bentonite & cement Did any strata contain unusable water? [X] Yes [ ] No Type of water? Depth of strata 260' - 265' Method of sealing strata off pressure cemented

(10) WATER LEVELS: Static level 10 ft. below land surface Date Oct. 24. 61 Artesian pressure lbs. per square inch Date

Log Accepted by: [Signed] Sam E. Stoller Date , 19 (Owner)

(11) WELL TESTS: Drawdown is amount water level is lowered below static level Was a pump test made? [ ] Yes [X] No. If yes, by whom?

Table with columns: Yield, gal./min. with, ft. drawdown after, hrs. Rows include Baller test 45 gal./min. with 35 ft. drawdown after 1 hrs.

(12) WELL LOG: Diameter of well 6 inches. Depth drilled 324 ft. Depth of completed well 324 ft.

Formation: Describe by color, character, size of material and structure, and show thickness of aquifers and the kind and nature of the material in each stratum penetrated, with at least one entry for each change of formation.

Table with columns: MATERIAL, FROM, TO. Rows include brown sandy clay, blue silt, brown clay, brown black, white rock, blue clay, brown brown silt, brown sand (wbf), hard rock could be boulders, hard rock, soft black rock (wbf).

There was about 30 gpm in the sand at 265' but the blue silt came down, pumped in 8 sks cement & shut off water & sand

Work started Sept 14 19 61 Completed Oct 24 19 61

(13) PUMP: Manufacturer's Name Type: H.P.

Well Driller's Statement: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

NAME A.J. Gaunt (Person, firm, or corporation) (Type or print) Address 3270 S.W. 185 Ave Aloha, Ore. Driller's well number # 956-81 [Signed] A.J. Gaunt (Well Driller) License No. 4 Date Oct 24 19 61