

NOTICE TO WATER WELL CONTRACTOR
The original and first copy of this report
are to be filed with the

WATER RESOURCES DEPARTMENT,
SALEM, OREGON 97310
within 30 days from the date
of well completion.

NC WATER WELL REPORT WASH

STATE OF OREGON
(Please type or print)

013472

State Well No.

2S/3W-12

State Permit No.

RECEIVED
JUN 16 1978
WATER RESOURCES DEPT.
SALEM, OREGON

(Do not write above this line)

(1) OWNER:

Name Laurel Community Church
Address Rt 2 Box 61
HILLSBORO, OR 97123

(2) TYPE OF WORK (check):

New Well Deepening Reconditioning Abandon

If abandonment, describe material and procedure in Item 12.

(3) TYPE OF WELL:

Rotary Driven
 Jetted
Dug Bored

(4) PROPOSED USE (check):

Domestic Industrial Municipal
Irrigation Test Well Other

(5) CASING INSTALLED:

Threaded Welded
6 5/8 OD Diam. from 0 ft. to 217 ft. Gage .250

(6) PERFORATIONS:

Perforated? Yes No.

Type of perforator used

Size of perforations in. by in.
perforations from ft. to ft.
perforations from ft. to ft.
perforations from ft. to ft.

(7) SCREENS:

Well screen installed? Yes No

Manufacturer's Name
Type Model No.
Diam. Slot size Set from ft. to ft.
Diam. Slot size Set from ft. to ft.

(8) WELL TESTS:

Drawdown is amount water level is
lowered below static level

Is a pump test made? Yes No If yes, by whom?
Yield: gal./min. with ft. drawdown after hrs.
" " " " "
" " " " "
Packer test 40 gal./min. with 80 ft. drawdown after 1 1/2 hrs.
Artesian flow g.p.m.
Temperature of water Depth artesian flow encountered ft.

(9) CONSTRUCTION:

Well seal—Material used cement
Well sealed from land surface to 22 ft.
Diameter of well bore to bottom of seal 12 in.
Diameter of well bore below seal 8 in.
Number of sacks of cement used in well seal 8 sacks
How was cement grout placed? Pressure grouted at end
of casing from 217ft. to 195 ft.
Was a drive shoe used? Yes No Plugs NO Size: location ft.
Did any strata contain unusable water? Yes No
Type of water? mineral depth of strata 100 ft
Method of sealing strata off cased & cemented off -147ft
Was well gravel packed? Yes No Size of gravel:
Gravel placed from ft. to ft.

(10) LOCATION OF WELL:

County Washington Driller's well number
1/4 1/4 Section 12 T. 2S R. 3W W.M.
Bearing and distance from section or subdivision corner C-C-C

(11) WATER LEVEL: Completed well.

Depth at which water was first found 100 ft.
Static level 30 ft. below land surface. Date 5-18-78
Artesian pressure lbs. per square inch. Date

(12) WELL LOG:

Diameter of well below casing 6" ft.
Depth drilled 278 ft. Depth of completed well 278 ft.

Formation: Describe color, texture, grain size and structure of materials;
and show thickness and nature of each stratum and aquifer penetrated,
with at least one entry for each change of formation. Report each change in
position of Static Water Level and indicate principal water-bearing strata.

MATERIAL	From	To	SWL
brown clay silt	0	23	
blue clay	23	45	
blue brown clay	45	86	
soft brown rock	86	100	
boulders	100	105	
soft light brown rock	105	143	
boulders	143	147	
soft brown rock	147	206	
blue black clay	206	210	
med hard basalt	210	213	
basalt	213	217	
med hard basalt	217	241	
hard basalt	241	247	
med hard broken basalt	247	247.8	30ft

Work started April 24, 78 Completed May 18, 19 78
Date well drilling machine moved off of well May 18, 19 78

Drilling Machine Operator's Certification:

This well was constructed under my direct supervision.
Materials used and information reported above are true to my
best knowledge and belief.

[Signed] John H. Meeber Date 5-24, 19 78
(Drilling Machine Operator)

Drilling Machine Operator's License No. 50

Water Well Contractor's Certification:

This well was drilled under my jurisdiction and this report is
true to the best of my knowledge and belief.

Name JOHN MEEBER WELL DRILLING
(Person, firm or corporation) (Type or print)

Address 2902 Portland Rd., Newberg, OR 97132

[Signed] John H. Meeber
(Water Well Contractor)

Contractor's License No. 111 Date May 24, 19 78