

NOTICE TO WATER WELL CONTRACTOR
The original and first copy of this report are to be filed with the

STATE ENGINEER, SALEM, OREGON 97310
within 30 days from the date of well completion.

RECEIVED
MAY 20 1964
STATE ENGINEER
SALEM, OREGON

WATER WELL REPORT

WASH

013648

3/1W-2D

State Well No.

State Permit No.

G-3698

(1) OWNER:

Name Lee Thompson
Address Rt. 2
Sherwood, Ore

(2) LOCATION OF WELL:

County Washington Driller's well number 1564
NW 1/4 NW 1/4 Section 2 T. 3S R. 1W W.M.
Bearing and distance from section or subdivision corner

(3) TYPE OF WORK (check):

New Well Deepening Reconditioning Abandon
Abandonment, describe material and procedure in Item 12.

(4) PROPOSED USE (check):

Domestic Industrial Municipal
Irrigation Test Well Other

(5) TYPE OF WELL:

Rotary Driven
Cable Jetted
Dug Bored

(6) CASING INSTALLED:

Threaded Welded
6 " Diam. from 0 ft. to 318.6" ft. Gage .250
" Diam. from ft. to ft. Gage
" Diam. from ft. to ft. Gage

(7) PERFORATIONS:

Perforated? Yes No

Type of perforator used
Size of perforations in. by in.
..... perforations from ft. to ft.
..... perforations from ft. to ft.
..... perforations from ft. to ft.
..... perforations from ft. to ft.
..... perforations from ft. to ft.

(8) SCREENS:

Well screen installed? Yes No

Manufacturer's Name
Type Model No.
..... Slot size Set from ft. to ft.
Diam. Slot size Set from ft. to ft.

(9) CONSTRUCTION:

Well seal—Material used in seal Cement
Depth of seal 31 ft. Was a packer used? no
Diameter of well bore to bottom of seal 10 in.
Were any loose strata cemented off? Yes No Depth
Was a drive shoe used? Yes No
Was well gravel packed? Yes No Size of gravel:
Gravel placed from ft. to ft.
Did any strata contain unusable water? Yes No
Type of water? depth of strata
Method of sealing strata off

(10) WATER LEVELS:

Static level 40 ft. below land surface Date 4/28/64
Artesian pressure lbs. per square inch Date

(11) WELL TESTS:

Drawdown is amount water level is lowered below static level

Was a pump test made? Yes No If yes, by whom?
Yield: gal./min. with ft. drawdown after hrs.
" " " " "
" " " " "
Bailer test 50 gal./min. with 20 ft. drawdown after 2 hrs.
Artesian flow g.p.m. Date
Temperature of water 50 Was a chemical analysis made? Yes No

(12) WELL LOG:

Diameter of well below casing 6

Depth drilled 130 ft. Depth of completed well 130 ft.

Formation: Describe by color, character, size of material and structure, and show thickness of aquifers and the kind and nature of the material in each stratum penetrated, with at least one entry for each change of formation.

MATERIAL	FROM	TO
Clay & boulders	0	4
Brown clay conglomerate	4	14
Dark grey rock	14	31
Greenish grey rock	31	49
Brown rock	49	60
grey rock	60	62
Red rock (water)	62	69
Brown rock yellow seams	69	79
Grey rock	79	99
Soft black rock (water)	99	104
Grey rock	104	130

Work started 4/13/64 19 Completed 4/29/64 19
Date well drilling machine moved off of well 4/30/64 19

(13) PUMP:

Manufacturer's Name Sumo
Type: Submersible H.P. 2

Water Well Contractor's Certification:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

NAME Steinman Bros
(Person, firm or corporation) (Type or print)

Address Milwaukie, Ore.

Drilling Machine Operator's License No. 67

[Signed] Steinman Bros
(Water Well Contractor)

Contractor's License No. 1 Date 5/6/64 19