

NOTICE TO WATER WELL CONTRACTOR

The original and first copy of this report are to be filed with the

STATE ENGINEER, SALEM, OREGON 97310 within 30 days from the date of well completion.

**RECEIVED**  
JUN 21 1967  
STATE ENGINEER  
SALEM, OREGON

WATER WELL REPORT

STATE OF OREGON

(Please type or print)

Wash 2015

State Well No. ~~3~~ 3/2w-11  
H  
State Permit No.

(1) OWNER:

Name ELTON C. PHILLIPS  
Address 15165 SW SUNRISE LANE  
TIGARD, ORE

(2) LOCATION OF WELL:

County Wash Driller's well number 23  
SE 1/4 NE 1/4 Section 11 T. 3S R. 2W W.M.  
Bearing and distance from section or subdivision corner LOT  
No. 7, Chehalis Mountain SUB-  
VISION

(3) TYPE OF WORK (check):

Well  Deepening  Reconditioning  Abandon   
If abandonment, describe material and procedure in Item 12.

(4) PROPOSED USE (check):

Domestic  Industrial  Municipal  Rotary  Driven   
Irrigation  Test Well  Other  Cable  Jetted   
Dug  Bored

(5) TYPE OF WELL:

(6) CASING INSTALLED:

Threaded  Welded   
6" Diam. from 0 ft. to 31 ft. Gage 250  
" Diam. from ft. to ft. Gage  
" Diam. from ft. to ft. Gage

(7) PERFORATIONS:

Perforated?  Yes  No

Type of perforator used

Size of perforations in. by in.  
perforations from ft. to ft.  
perforations from ft. to ft.  
perforations from ft. to ft.  
perforations from ft. to ft.  
perforations from ft. to ft.

(8) SCREENS:

Well screen installed?  Yes  No

Manufacturer's Name  
Model No.  
Diam. Slot size Set from ft. to ft.  
Diam. Slot size Set from ft. to ft.

(9) CONSTRUCTION:

Well seal—Material used in seal BENTONITE  
Depth of seal 30 ft. Was a packer used? SAW  
Diameter of well bore to bottom of seal 9 in.  
Were any loose strata cemented off?  Yes  No Depth  
Was a drive shoe used?  Yes  No  
Was well gravel packed?  Yes  No Size of gravel:  
Gravel placed from ft. to ft.  
Did any strata contain unusable water?  Yes  No  
Type of water? depth of strata  
Method of sealing strata off

(10) WATER LEVELS:

Static level 0 ft. below land surface Date 6-5-67  
Artesian pressure 6 lbs. per square inch Date 6-5-67

(11) WELL TESTS:

Drawdown is amount water level is lowered below static level

Was a pump test made?  Yes  No If yes, by whom? OPERATOR  
Yield: 45 gal./min. with 320 ft. drawdown after 1 hrs.

Baller test gal./min. with ft. drawdown after hrs.

Artesian flow 7 g.p.m. Date 6-5-67

Temperature of water 58° Was a chemical analysis made?  Yes  No

(12) WELL LOG:

Diameter of well below casing 6"

Depth drilled 320 ft. Depth of completed well 320 ft.

Formation: Describe by color, character, size of material and structure, and show thickness of aquifers and the kind and nature of the material in each stratum penetrated, with at least one entry for each change of formation.

MATERIAL	FROM	TO
BROWN SOIL	0	3
RED CLAY	3	19
BROWN LOAM	19	24
BLACK BASALT	24	80
POROUS BLACK BASALT	80	85
BLACK BASALT	85	250
POROUS BASALT (WATER)	250	265
BLACK BASALT	265	272
BROWN POROUS (WATER)	272	285
BLACK BASALT	285	305
POROUS BLACK (WATER)	305	315
BLACK BASALT	315	320

Work started 6-2 1967 Completed 6-5 1967  
Date well drilling machine moved off of well 6-5 1967

(13) PUMP:

Manufacturer's Name  
Type: H.P.

Water Well Contractor's Certification:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

NAME RAYMOND A. BORCHERS  
(Person, firm or corporation) (Type or print)  
Address RT. 3, Box 271A Sherwood, ORE

Drilling Machine Operator's License No. 305

[Signed] Raymond A. Borchers  
(Water Well Contractor)

Contractor's License No. 404 Date 6-6 1967