NOTICE TO WATER WELL CONTRACTOR
The original and first copy of this report are to be filed with the
STATE ENGINEER, SALEM, OREGON 97310 within 30 days from the date of well completion.

453 Wash

WATER WELL REPORT
STATE OF OREGON
(Please type or print)
(Do not write above this line)

RECEIVED
MAY 18 1973
STATE ENGINEER
SALEM, OREGON

State Well No. 2N/2W-34
State Permit No. 453 Wash

(1) OWNER:
Name Melvin C. Schultz
Address 10300 S. W. Denny Road Beaverton, Oregon

(2) TYPE OF WORK (check):
New Well ☒ Deepening ☐ Reconditioning ☐ Abandon ☐
If abandonment, describe material and procedure in Item 12.

(3) TYPE OF WELL:
Rotary ☒ Driven ☐
Cable ☐ Jetted ☐
D[redacted] ☐ Bored ☐

(4) PROPOSED USE (check):
Domestic ☒ Industrial ☐ Municipal ☐
Irrigation ☐ Test Well ☐ Other ☐

(5) CASING INSTALLED:
Threaded ☐ Welded ☒
6 " Diam. from 0 ft. to 101 ft. Gage ¼ wall
" Diam. from ft. to ft. Gage
" Diam. from ft. to ft. Gage

(6) PERFORATIONS:
Perforated? ☐ Yes ☒ No
Type of perforator used
Size of perforations in. by in.
perforations from ft. to ft.
perforations from ft. to ft.
perforations from ft. to ft.

(7) SCREENS:
Well screen installed? ☐ Yes ☒ No
Manufacturer's Name
Type Model No.
Diam. Slot size Set from ft. to ft.
Diam. Slot size Set from ft. to ft.

(8) WELL TESTS:
Drawdown is amount water level is lowered below static level
Was a pump test made? ☐ Yes ☒ No If yes, by whom?
[redacted]: gal./min. with ft. drawdown after hrs.
" " " "
" " " "
air
Bailer test 25 gal./min. with 45 ft. drawdown after 1 hrs.
[redacted]sian flow g.p.m.
Temperature of water Depth artesian flow encountered ft.

(9) CONSTRUCTION:
Well seal—Material used cement
Well sealed from land surface to 101 ft.
Diameter of well bore to bottom of seal 9 in.
Diameter of well bore below seal 6 in.
Number of sacks of cement used in well seal 12 sacks
Number of sacks of bentonite used in well seal sacks
Brand name of bentonite
Number of pounds of bentonite per 100 gallons of water lbs./100 gals.
Was a drive shoe used? ☐ Yes ☒ No Plugs Size: location ft.
Did any strata contain unusable water? ☐ Yes ☒ No
Type of water? depth of strata
Method of sealing strata off
Was well gravel packed? ☐ Yes ☒ No Size of gravel:
Gravel placed from ft. to ft.

(10) LOCATION OF WELL:
County Washington Driller's well number
¼ ¼ Section 34 T. 2-N R. 2-W W.M.
Bearing and distance from section or subdivision corner

(11) WATER LEVEL: Completed well.
Depth at which water was first found 85 ft.
Static level 155 ft. below land surface. Date 5-12-73
Artesian pressure lbs. per square inch. Date

(12) WELL LOG:
Diameter of well below casing 6
Depth drilled 220 ft. Depth of completed well 220 ft.

Formation: Describe color, texture, grain size and structure of materials; and show thickness and nature of each stratum and aquifer penetrated, with at least one entry for each change of formation. *Report each change in position of Static Water Level and indicate principal water-bearing strata.*

MATERIAL	From	To	SWL
Top soil	0	2	
Brown clay	2	48	
Brown sandy clay	48	85	
Brown med. rock	85	135	
Blue med. rock	135	163	
Brown lava rock	163	175	
Blue med. rock	175	197	
Brown lava rock	197	205	
Blue med. rock	205	220	

Work started 5-11-73 19 Completed 5-12-73 19
Date well drilling machine moved off of well 5-12-73 19

Drilling Machine Operator's Certification:
This well was constructed under my direct supervision. Materials used and information reported above are true to my best knowledge and belief.
[Signed] Ralph Turner (Drilling Machine Operator) Date 5-15-73 19
Drilling Machine Operator's License No. 254

Water Well Contractor's Certification:
This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.
Name Ralph Turner Drilling Co. (Person, firm or corporation) (Type or print)
Address Rte 1 Box 141 Hillsboro, Oregon 97123
[Signed] Ralph Turner (Water Well Contractor)
Contractor's License No. 247 Date 5-15-73, 19

(USE ADDITIONAL SHEETS IF NECESSARY)

SP*45656-119