NOTICE TO WATER WELL CONTRACTOR
The original and first copy of this report are to be filed with the
STATE ENGINEER, SALEM, OREGON 97310
within 30 days from the date of well completion.

RECEIVED
AUG 2 - 1972
STATE ENGINEER
SALEM, OREGON

WATER WELL REPORT
STATE OF OREGON
(Please type or print)
(Do not write above this line)

(532) Wash

State Well No. 2N/4W-25aa

State Permit No. .....

G6060

(1) OWNER:
Name WILLIAM E DAME
Address Rt 1 Box 180 BANKS Oregon 97310

(2) TYPE OF WORK (check):
New Well ☒ Deepening ☐ Reconditioning ☐ Abandon ☐
If abandonment, describe material and procedure in Item 12.

(3) TYPE OF WELL:
Rotary ☐ Driven ☐
Cable ☒ Jetted ☐
Dug ☐ Bored ☐

(4) PROPOSED USE (check):
Domestic ☒ Industrial ☐ Municipal ☐
Irrigation ☐ Test Well ☐ Other ☐

(5) CASING INSTALLED: Threaded ☐ Welded ☒
6" Diam. from 0 ft. to 98 ft. Gage 1/4
..." Diam. from ..... ft. to ..... ft. Gage .....
..." Diam. from ..... ft. to ..... ft. Gage .....

(6) PERFORATIONS: Perforated? ☐ Yes ☒ No.
Type of perforator used
Size of perforations ..... in. by ..... in.
..... perforations from ..... ft. to ..... ft.
..... perforations from ..... ft. to ..... ft.
..... perforations from ..... ft. to ..... ft.

(7) SCREENS: Well screen installed? ☐ Yes ☒ No
Manufacturer's Name .....
Type ..... Model No. .....
Diam. ..... Slot size ..... Set from ..... ft. to ..... ft.
Diam. ..... Slot size ..... Set from ..... ft. to ..... ft.

(8) WELL TESTS: Drawdown is amount water level is lowered below static level
Was a pump test made? ☐ Yes ☒ No If yes, by whom?
Yield: ..... gal./min. with ..... ft. drawdown after ..... hrs.
" " " "
" " " "
Bailer test 20 gal./min. with 45 ft. drawdown after 1 hrs.
Artesian flow ..... g.p.m.
Temperature of water 54 Depth artesian flow encountered ..... ft.

(9) CONSTRUCTION:
Well seal—Material used Cement
Well sealed from land surface to 19 ft.
Diameter of well bore to bottom of seal 12 in.
Diameter of well bore below seal 6 in.
Number of sacks of cement used in well seal 10 sacks
Number of sacks of bentonite used in well seal ..... sacks
Brand name of bentonite .....
Number of pounds of bentonite per 100 gallons of water ..... lbs./100 gals.
Was a drive shoe used? ☒ Yes ☐ No Plugs ..... Size: location ..... ft.
Did any strata contain unusable water? ☐ Yes ☐ No
Type of water? ..... depth of strata
Method of sealing strata off
Was well gravel packed? ☐ Yes ☒ No Size of gravel: .....
Gravel placed from ..... ft. to ..... ft.

(10) LOCATION OF WELL:
County WASHINGTON Driller's well number
NE ¼ NE ¼ Section 25 T 2N R. 4W W.M.
Bearing and distance from section or subdivision corner

(11) WATER LEVEL: Completed well.
Depth at which water was first found 102 ft.
Static level 10 ft. below land surface. Date 7-29-72
Artesian pressure ..... lbs. per square inch. Date

(12) WELL LOG: Diameter of well below casing 6
Depth drilled 105 ft. Depth of completed well 105 ft.

Formation: Describe color, texture, grain size and structure of materials; and show thickness and nature of each stratum and aquifer penetrated, with at least one entry for each change of formation. *Report each change in position of Static Water Level and indicate principal water-bearing strata.*

MATERIAL	From	To	SWL
SOIL BROWN SANDY	0	4	
BROWN CLAY	4	70	
Fine SAND & WOOD			
BLUE CLAY	77	100	
GRAVEL Medium	100	105	

Work started 7 - 27 1972 Completed 7-29 1972
Date well drilling machine moved off of well 7-29 1972

Drilling Machine Operator's Certification:
This well was constructed under my direct supervision. Materials used and information reported above are true to my best knowledge and belief.
[Signed] Cyril Vandehey (Drilling Machine Operator) Date 7-31, 1972
Drilling Machine Operator's License No. 42

Water Well Contractor's Certification:
This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.
Name CYRIL VANDEHEY (Person, firm or corporation) (Type or print)
Address Rt 2 Box 262 Forest Grove Oregon
[Signed] Cyril Vandehey (Water Well Contractor)
Contractor's License No. 353 Date 7-31, 1972

(USE ADDITIONAL SHEETS IF NECESSARY)

SP*45656-119