

NOTICE TO WATER WELL CONTRACTOR

The original and first copy of this report are to be filed with the

STATE ENGINEER, SALEM, OREGON within 30 days from the of well completion.

WATER WELL REPORT

RECEIVED STATE OF OREGON NOV 20 1968 STATE ENGINEER SALEM OREGON

STATE OF OREGON (Please type or print) (Do not write above this line)

State Well No. 1N/2W-15 State Permit No.

WASH 5345

(1) OWNER:

Name West Union School Address Cedar Mills Road Hillsboro, Ore.

(11) LOCATION OF WELL:

County Washington Driller's well number 1/4 Section 15 T. 1-N R. 2-W W.M. Bearing and distance from section or subdivision corner

(2) TYPE OF WORK (check):

New Well [ ] Deepening [x] Reconditioning [ ] Abandon [ ] If abandonment, describe material and procedure in Item 12.

(3) TYPE OF WELL:

Rotary [x] Cable [ ] Dug [ ] Driven [ ] Jetted [ ] Bored [ ]

(4) PROPOSED USE (check):

Domestic [ ] Industrial [ ] Municipal [ ] Irrigation [ ] Test Well [ ] Other [x]

(12) WELL LOG:

Diameter of well below casing 6 inch. Depth drilled 135 ft. Depth of completed well 230 ft.

Formation: Describe color, texture, grain size and structure of materials; and show thickness and nature of each stratum and aquifer penetrated, with at least one entry for each change of formation. Report each change in position of Static Water Level as drilling proceeds. Note drilling rates.

Table with columns: MATERIAL, From, To, SWL. Rows include Blue clay, Brown sand and clay, Brown clay, Brown soft sandstone, Black rock.

(5) CASING INSTALLED:

5-9/16" Diam. from 110 ft. to 120 ft. Gage 10 gage. Threaded [ ] Welded [x]

(6) PERFORATIONS:

Perforated? [x] Yes [ ] No. Type of perforator used torch. Size of perforations 1/8 in. by 6 in. 160 perforations from 150 ft. to 230 ft.

(7) SCREENS:

Well screen installed? [ ] Yes [x] No. Manufacturer's Name, Type, Model No., Diam., Slot size, Set from ft. to ft.

(8) WATER LEVEL: Completed well.

Static level 60 ft. below land surface Date 11-23-68. Artesian pressure lbs. per square inch Date

(9) WELL TESTS:

Drawdown is amount water level is lowered below static level. Was a pump test made? [ ] Yes [x] No. Yield: gal./min. with ft. drawdown after hrs. Baller test 30 gal./min. with 60 ft. drawdown after 1 hrs. Temperature of water Was a chemical analysis made? [ ] Yes [x] No

(10) CONSTRUCTION:

Well seal—Material used, Depth of seal, Diameter of well bore to bottom of seal, Were any loose strata cemented off? [ ] Yes [x] No, Was a drive shoe used? [ ] Yes [x] No, Did any strata contain unusable water? [ ] Yes [x] No, Type of water? depth of strata, Method of sealing strata off, Was well gravel packed? [ ] Yes [x] No, Size of gravel, Gravel placed from ft. to ft.

Drilling Machine Operator's Certification:

This well was constructed under my direct supervision. Materials used and information reported above are true to my best knowledge and belief.

[Signed] Ralph Turner Date 11-26, 1968 (Drilling Machine Operator)

Drilling Machine Operator's License No. 254

Water Well Contractor's Certification:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

NAME Ralph Turner Drilling Co. (Person, firm or corporation) (Type or print)

Address Rte 1 Box 141 Hillsboro, Oregon

[Signed] Ralph Turner (Water Well Contractor)

Contractor's License No. 247 Date 11-26, 1968