NOTICE TO WATER WELL CONTRACTOR
The original and first copy of this report are to be filed with the

STATE ENGINEER, SALEM, OREGON 97310
within 30 days from the date of well completion.

WASH 5360

WATER WELL REPORT
STATE OF OREGON
(Please type or print)
(Do not write above this line)

RECEIVED
AUG 3 1976
WATER RESOURCES DEPT.
SALEM, OREGON

State Well No. .....
State Permit No. 1N/2W-16

(1) OWNER:
Name Marvin Suess
Address Rt 1 Bx 58 - Hillsboro, Ore

(2) TYPE OF WORK (check):
New Well [X] Deepening [ ] Reconditioning [ ] Abandon [ ]
If abandonment, describe material and procedure in Item 12.

(3) TYPE OF WELL:
Rotary [ ] Driven [ ]
Cable [X] Jetted [ ]
Dug [ ] Bored [ ]

(4) PROPOSED USE (check):
Domestic [X] Industrial [ ] Municipal [ ]
Irrigation [ ] Test Well [ ] Other [ ]

(5) CASING INSTALLED: Threaded [ ] Welded [X]
6" Diam. from 0 ft. to 122' ft. Gage 17#
..." Diam. from ... ft. to ... ft. Gage ...
..." Diam. from ... ft. to ... ft. Gage ...

PERFORATIONS: Perforated? [ ] Yes [X] No.
Type of perforator used
Size of perforations in. by in.
... perforations from ... ft. to ... ft.
... perforations from ... ft. to ... ft.
... perforations from ... ft. to ... ft.

(7) SCREENS: Well screen installed? [ ] Yes [X] No
Manufacturer's Name ...
Type ... Model No. ...
Diam. ... Slot size ... Set from ... ft. to ... ft.
Diam. ... Slot size ... Set from ... ft. to ... ft.

(8) WELL TESTS: Drawdown is amount water level is lowered below static level
Was a pump test made? [ ] Yes [X] No If yes, by whom?
Yield: gal./min. with ft. drawdown after hrs.
" " " "
" " " "
Bailer test 8-10 gal./min. with 70 ft. drawdown after 1 hrs.
Artesian flow No g.p.m.
Temperature of water Normal Depth artesian flow encountered — ft.

(9) CONSTRUCTION:
Well seal—Material used Bentonite
Well sealed from land surface to 25' ft.
Diameter of well bore to bottom of seal 10 in.
Diameter of well bore below seal 6 in.
Number of sacks of cement used in well seal 0 sacks
Number of sacks of bentonite used in well seal 3 sacks
Brand name of bentonite Yellowstone
Number of pounds of bentonite per 100 gallons of water 50# lbs./100 gals.
Was a drive shoe used? [ ] Yes [X] No Plugs ... Size: location ... ft.
Did any strata contain unusable water? [ ] Yes [X] No
Type of water? depth of strata
Method of sealing strata off
Was well gravel packed? [ ] Yes [X] No Size of gravel: ...
Gravel placed from ... ft. to ... ft.

(10) LOCATION OF WELL:
County Wash Driller's well number
¼ ¼ Section 16 T. 1N R. 2W W.M.
Bearing and distance from section or subdivision corner

(11) WATER LEVEL: Completed well.
Depth at which water was first found 135 ft.
Static level 30 ft. below land surface. Date Aug 1, 76
Artesian pressure lbs. per square inch. Date

(12) WELL LOG: Diameter of well below casing 6
Depth drilled 135 ft. Depth of completed well 135 ft.
Formation: Describe color, texture, grain size and structure of materials; and show thickness and nature of each stratum and aquifer penetrated, with at least one entry for each change of formation. *Report each change in position of Static Water Level and indicate principal water-bearing strata.*

MATERIAL	From	To	SWL
Brn Clay	0	15	
Blue ✓	15	30	
White ✓	30	45	
Brn ✓	45	90	
Blue ✓	90	125	
Brown Clay + Sand	125	135	30

Work started July 25 1976 Completed Aug 1 1976
Date well drilling machine moved off of well Aug 2 1976

Drilling Machine Operator's Certification:
This well was constructed under my direct supervision. Materials used and information reported above are true to my best knowledge and belief.
[Signed] A J Gaunt (Drilling Machine Operator) Date Aug 2, 1976.
Drilling Machine Operator's License No. 4

Water Well Contractor's Certification:
This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.
Name A.V. Gaunt (Person, firm or corporation) (Type or print)
Address Aloha, Ore
[Signed] A J Gaunt (Water Well Contractor)
Contractor's License No. 4 Date Aug 2, 1976

(USE ADDITIONAL SHEETS IF NECESSARY)

SP*45656-119