

NOTICE TO WATER WELL CONTRACTOR

The original and first copy of this report are to be filed with the

STATE ENGINEER, SALEM, OREGON 97310 within 30 days from the date of well completion.

RECEIVED
NOV 7 1966
STATE ENGINEER

WATER WELL REPORT

STATE OF OREGON
(Please type or print)

WASH 5508
G-3738

State Well No. 1N/2W-1E 21A

State Permit No. _____

(1) OWNER: SALEM, OREGON

Name Mr. H.R. Wittenhagen
Address Rt. 1 Box 60H Hillsboro Ore.

(2) LOCATION OF WELL:

County Wash. Driller's well number _____
1/4 Section 16 T. 1 N R. 2 W W.M.
Bearing and distance from section or subdivision corner _____

(3) TYPE OF WORK (check):

New Well Deepening Reconditioning Abandon
Abandonment, describe material and procedure in Item 12.

(4) PROPOSED USE (check):

Domestic Industrial Municipal Rotary Driven
Irrigation Test Well Other Cable Jetted
Stock Watering Dug Bored

(5) TYPE OF WELL:

(6) CASING INSTALLED: Threaded Welded

5 6" Diam. from Plus 6" to 124 ft. Gage 17#
9/16" Diam. from 122 ft. to 134 ft. Gage 10
" Diam. from _____ ft. to _____ ft. Gage _____

(7) PERFORATIONS:

Liner Perforated Perforated? Yes No
Type of perforator used Torch
Size of perforations 1/8 By 1/2 by 12 in.
40 perforations from 124 ft. to 134 ft.
192 3 by 1/8 perforations from 130 ft. to 134 ft.
perforations from _____ ft. to _____ ft.
perforations from _____ ft. to _____ ft.
perforations from _____ ft. to _____ ft.

(8) SCREENS:

Well screen installed? Yes No

Manufacturer's Name _____
Type _____ Model No. _____
Slot size _____ Set from _____ ft. to _____ ft.
Diam. _____ Slot size _____ Set from _____ ft. to _____ ft.

(9) CONSTRUCTION:

Well seal—Material used in seal Bentonite
Depth of seal 23 ft. Was a packer used? No
Diameter of well bore to bottom of seal 10 in.
Were any loose strata cemented off? Yes No Depth _____
Was a drive shoe used? Yes No 6" coupling
Was well gravel packed? Yes No Size of gravel: _____
Gravel placed from _____ ft. to _____ ft.
Did any strata contain unusable water? Yes No
Type of water? _____ depth of strata _____
Method of sealing strata off _____

(10) WATER LEVELS:

Static level 27 ft. below land surface Date 11-2-66
Artesian pressure NO lbs. per square inch Date _____

(11) WELL TESTS:

Drawdown is amount water level is lowered below static level

Was a pump test made? Yes No If yes, by whom?
Yield: gal./min. with ft. drawdown after hrs.
" " " " "
" " " " "
Bailer test 12 gal./min. with 73 ft. drawdown after 2 hrs.
Artesian flow NO g.p.m. Date _____
Temperature of water _____ Was a chemical analysis made? Yes No

(12) WELL LOG:

Diameter of well below casing 6"

Depth drilled 134 ft. Depth of completed well 134 ft.

Formation: Describe by color, character, size of material and structure, and show thickness of aquifers and the kind and nature of the material in each stratum penetrated, with at least one entry for each change of formation.

MATERIAL	FROM	TO
Top Soil	0	1 1/2
Sub Soil	1 1/2	3
Hard pan	3	12
Brown sand and br. clay	12	23
Cemented Blue sand	23	29
Fine blue sand & soft Blue clay	29	49
Hard blue clay	49	54
Very thin layers sd. & clay	54	61 1/2
Yellow clay	61 1/2	##67
Brown clay	67	76
Very fine brown sand	76	79
Hard brown clay	79	99
soft blue clay	99	123
Hard blue clay	123	127
Layers clay and sand very fine	127	134
Blue clay	134	

Work started Oct. 25 19 Completed 11-2-66 19
Date well drilling machine moved off of well 11-3-66 19

(13) PUMP:

Manufacturer's Name _____
Type: _____ H.P. _____

Water Well Contractor's Certification:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

NAME Lee Barton Well Drilling
(Person, firm or corporation) (Type or print)

Address 25805 N.W. Evergreen st. Hillsboro Or

Drilling Machine Operator's License No. 2

[Signed] Lee Barton
(Water Well Contractor)

Contractor's License No. 28 Date 11-3-66, 19