

RECEIVED
OCT 15 1959

WATER WELL REPORT
STATE OF OREGON

WASH
5949

IN 3W-1F11 9

File Original and
First Copy with the
STATE ENGINEER,
SALEM, OREGON

STATE ENGINEER

State Well No.

State Permit No. 983

(1) OWNER:

Name Leonard W. Walker
Address RT 1 - Box 345 Corvallis

(2) LOCATION OF WELL:

County Wash Owner's number, if any -
SE 1/4 NW 1/4 Section 1 T. 1-N R. 3 W. W.M.
Bearing and distance from section or subdivision corner
S 46° 0' 2600 FEET FROM THE
NW CORNER SEC. 1 T. 1 R. 3 W

(3) TYPE OF WORK (check):

New Well Deepening Reconditioning Abandon
If abandonment, describe material and procedure in Item 11.

(4) PROPOSED USE (check):

Domestic Industrial Municipal
Irrigation Test Well Other

(5) TYPE OF WELL:

Rotary Driven
Cable Jetted
Dug Bored

(6) CASING INSTALLED:

Threaded Welded
6" Diam. from 0 ft. to 275 ft. Gage 280
" Diam. from ft. to ft. Gage
" Diam. from ft. to ft. Gage

(7) PERFORATIONS:

Perforated? Yes No

Type of perforator used

SIZE of perforations in. by in.
..... perforations from ft. to ft.
..... perforations from ft. to ft.
..... perforations from ft. to ft.
..... perforations from ft. to ft.

(8) SCREENS:

Well screen installed Yes No

Manufacturer's Name Johnson
Type Model No.
Diam. 5 1/4 Slot size 0.10 Set from 270 ft. to 300 ft.
..... Slot size Set from ft. to

(9) CONSTRUCTION:

Was well gravel packed? Yes No Size of gravel:
Gravel placed from ft. to ft.
Was a surface seal provided? Yes No To what depth? ft.
Material used in seal - Cement
Did any strata contain unusable water? Yes No
Type of water? Hard Disinfect Depth of strata 12 ft
Method of sealing strata off Drone Packing Post.

(10) WATER LEVELS:

Static level 39 ft. below land surface Date
Artesian pressure lbs. per square inch Date

Log Accepted by:

[Signed] Date 19.....
(Owner)

(11) WELL TESTS:

Drawdown is amount water level is lowered below static level

Was a pump test made? Yes No If yes, by whom? -
Yield: 20 gal./min. with 70 ft. drawdown after 10 hrs.
" " " " " "
" " " " " "
" " " " " "
Bailer test 15 gal./min. with 59 ft. drawdown after 1 hrs.
Artesian flow g.p.m. Date
Temperature of water Was a chemical analysis made? Yes No

(12) WELL LOG:

Diameter of well 6 inches.

Depth drilled 300 ft. Depth of completed well 300 ft.

Formation: Describe by color, character, size of material and structure, and show thickness of aquifers and the kind and nature of the material in each stratum penetrated, with at least one entry for each change of formation.

MATERIAL	FROM	TO
Top Soil	0	4
Blue Sandy Clay	4	60
Heavy Blue Sand	60	132
Yellow Clay	132	156
Blue Clay	156	191
Yellow Clay	191	226
Blue Clay	226	247
Red Clay	247	269
Dark Sandy Clay	269	271
Blue Clay	271	283
Coarse Sand	283	296
Blue Clay	296	300

Work started 19..... Completed 19.....

(13) PUMP:

Manufacturer's Name Jaenzzi
Type: DEEP WELL JET H.P. 1

Well Driller's Statement:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

NAME Walter Burdick (Type or print)
Address 3340 S.W. Symons

Driller's well number

[Signed] Walter Burdick (Well Driller)

License No. 168 Date Oct 13 1959