## NOTICE TO WATER WELL CONTRACTOR The original and first copy of this report are to be filed with the

STATE ENGINEER, SALEM, OREGON 97310 within 30 days from the date

State Well N/13W-26d

(Please type or print)/AY - 5 1977

of well completion. (Do not write al	bove this line)  ATER RESOURCES DEPT
(1) OWNER:	(18)ALENGAGRENOUF WELL:
Name Chuck Davis	County Washington Driller's well number 798
Address North Plains, Ore.	
MINITED FIGURES	SE 4 NW 4 Section 2 T. IN R. 3 W.M.
(2) TYPE OF WORK (check):	Bearing and distance from section or subdivision corner
New Well   Deepening □ Reconditioning □ Abandon □	The state of the s
If abandonment, describe material and procedure in Item 12.	
	(11) WATER LEVEL: Completed well.
(3) TYPE OF WELL: (4) PROPOSED USE (check):	Depth at which water was first found 432 ft.
Rotary   Driven   Domestic   Industrial   Municipal	Static level 50 ft. below land surface. Date 4-29-7
Dug   Bored   Irrigation   Test Well   Other	Artesian pressure Ibs. per square inch. Date
CASING INSTALLED: Threaded Welded W	(12) WELL LOG: Diameter of well below casing 4"
" Diam. fromft. toft. Gage	Depth drilled 450 ft. Depth of completed well 450 ft.
" Diam. fromft. toft. Gage	Formation: Describe color, texture, grain size and structure of materials;
	and show thickness and nature of each stratum and aquifer penetrated, with at least one entry for each change of formation. Report each change in
PERFORATIONS: Perforated?   Yes No.	position of Static Water Level and indicate principal water-bearing strata.
Type of perforator used	MATERIAL From To SWL
Size of perforations in. by in.	Top Soil 0 2
perforations from ft. to ft.	Clay Brown 2 57
perforations from ft. to ft.	Clay sandy Brown 57 88
perforations fromft. toft.	Clay sandy Red 88 107
(7) SCREENS: Well screen installed? □ Yes M No	
, and the second distribution of the party o	Clay Brown 130 156
Manufacturer's Name	Clay Blue 156 189
Diam. Slot size Set from ft. to ft.	Clay Brown 189 194 Clay Blue 194 241
Diam. Slot size Set from ft. to ft.	Sand fine Black 241 244
	Clay Blue 244 289
(8) WELL TESTS: Drawdown is amount water level is lowered below static level	Clay Gray 289 313
Was a pump test made? ☐ Yes ☐ No If yes, by whom?	C/ay Red 313 322
d: gal./min. with ft. drawdown after hrs.	Clay Brown 322 334
" " "	Clay Gray 334 356
<i>"</i>	C/44 Brown 356 366
Bailer test 20 gal./min. with 2 ft. drawdown after 1 hrs.	- Clay Yelkiw 366 374
	Sandstone Yellow 394 432
	Sandstone + Rock gray hard 432 450
perature of water Depth artesian flow encountered ft.	Work started 3-39 19 77 Completed 4-39 19 77
(9) CONSTRUCTION:	Date well drilling machine moved off of well 4-30 1977
Well seal-Material used <u>Cement</u>	Drilling Machine Operator's Certification:
Well sealed from land surface toft_	This well was constructed under my direct supervision.  Materials used and information reported above are true to my
Diameter of well bore to bottom of sealin.	best knowledge and belief.
Diameter of well bore below sealin.	[Signed] Bert Wewlarmank Date 5-2, 19.77
Number of sacks of cement used in well seal sacks	Drilling Machine Operator's License No
Number of sacks of bentonite used in well seal sacks	Drining Machine Operator's Enterior 110.
Brand name of bentonite	Water Well Contractor's Certification:
Number of pounds of bentonite per 100 gallons	This well was drilled under my jurisdiction and this report is
of waterlbs./100 gals.  Was a drive shoe used? Yes \( \sum \) No Plugs Size: location ft.	true to the best of my knowledge and belief.
Did any strata contain unusable water?    Yes  No	Name Bert Devloeminck (Person, firm or corporation) (Type or print)
Type of water? depth of strata	Address Rt. 1. Box 126-X, Cornelius Ore.
Method of sealing strata off	2100 .1
Was well gravel packed?   Yes No Size of gravel:	[Signed] Dest Wester Well Contractor)
Gravel placed fromft.	Contractor's License No. 563 Date 5-2 , 19.77
- Little Control of the Control of t	, Dave be and the second