

NOTICE TO WATER WELL CONTRACTOR

The original and first copy of this report are to be filed with the

STATE ENGINEER, SALEM, OREGON within 30 days from the date of well completion.

**RECEIVED**

DEC 21 1965

WATER WELL REPORT

STATE ENGINEER SALEM OREGON (Please type or print)

WASH 5993

State Well No. 1N/3W-5

State Permit No. \_\_\_\_\_

**(1) OWNER:**

Name Myron Duyck  
Address Rt. 1, Box 26, Banks, Oregon

**(2) LOCATION OF WELL:**

County Washington Driller's well number \_\_\_\_\_  
1/4 Section 5 T. 1 N. R. 3 W. W.M.  
Bearing and distance from section or subdivision corner \_\_\_\_\_

**(3) TYPE OF WORK (check):**

New Well  Deepening  Reconditioning  Abandon   
If abandonment, describe material and procedure in Item 12.

**(4) PROPOSED USE (check):**

Domestic  Industrial  Municipal   
Irrigation  Test Well  Other

**(5) TYPE OF WELL:**

Rotary  Driven   
Cable  Jetted   
Dug  Bored

**(6) CASING INSTALLED:**

Threaded  Welded   
6 " Diam. from 0 ft. to 375 ft. Gage 1/4  
" Diam. from \_\_\_\_\_ ft. to \_\_\_\_\_ ft. Gage \_\_\_\_\_  
" Diam. from \_\_\_\_\_ ft. to \_\_\_\_\_ ft. Gage \_\_\_\_\_

**(7) PERFORATIONS:**

Perforated?  Yes  No

Type of perforator used \_\_\_\_\_

Size of perforations in. by in.  
\_\_\_\_\_ perforations from \_\_\_\_\_ ft. to \_\_\_\_\_ ft.  
\_\_\_\_\_ perforations from \_\_\_\_\_ ft. to \_\_\_\_\_ ft.  
\_\_\_\_\_ perforations from \_\_\_\_\_ ft. to \_\_\_\_\_ ft.  
\_\_\_\_\_ perforations from \_\_\_\_\_ ft. to \_\_\_\_\_ ft.

**(8) SCREENS:**

Well screen installed?  Yes  No

Manufacturer's Name \_\_\_\_\_ Model No. \_\_\_\_\_  
Slot size \_\_\_\_\_ Set from \_\_\_\_\_ ft. to \_\_\_\_\_ ft.  
Diam. \_\_\_\_\_ Slot size \_\_\_\_\_ Set from \_\_\_\_\_ ft. to \_\_\_\_\_ ft.

**(9) CONSTRUCTION:**

Well seal—Material used in seal Bentanite  
Depth of seal 19 ft. Was a packer used? no  
Diameter of well bore to bottom of seal 10 in.  
Were any loose strata cemented off?  Yes  No Depth \_\_\_\_\_  
Was a drive shoe used?  Yes  No  
Was well gravel packed?  Yes  No Size of gravel: \_\_\_\_\_  
Gravel placed from \_\_\_\_\_ ft. to \_\_\_\_\_ ft.  
Did any strata contain unusable water?  Yes  No  
Type of water? \_\_\_\_\_ depth of strata \_\_\_\_\_  
Method of sealing strata off \_\_\_\_\_

**(10) WATER LEVELS:**

Static level 15 ft. below land surface Date 12-13-65  
Artesian pressure \_\_\_\_\_ lbs. per square inch Date \_\_\_\_\_

**(11) WELL TESTS:**

Drawdown is amount water level is lowered below static level Power

Was a pump test made?  Yes  No If yes, by whom? Pump, Pipe, and  
Yield: 70 gal./min. with 78 ft. drawdown after 4 hrs.

Bailer test \_\_\_\_\_ gal./min. with \_\_\_\_\_ ft. drawdown after \_\_\_\_\_ hrs.

Artesian flow \_\_\_\_\_ g.p.m. Date \_\_\_\_\_

Temperature of water 54 Was a chemical analysis made?  Yes  No

**(12) WELL LOG:**

Diameter of well below casing 6

Depth drilled 425 ft. Depth of completed well 425 ft.

Formation: Describe by color, character, size of material and structure, and show thickness of aquifers and the kind and nature of the material in each stratum penetrated, with at least one entry for each change of formation.

MATERIAL	FROM	TO
Soil, brown, silty	0	32
Clay, blue	32	40
Clay, brown	40	65
Sand and clay	65	180
Quick sand	180	240
Clay, brown	240	255
Clay, red	255	370
Rock, soft	370	425

Work started 11-10 1965 Completed 12-13 1965

Date well drilling machine moved off of well 12-13 1965

**(13) PUMP:**

Manufacturer's Name none  
Type: \_\_\_\_\_ H.P. \_\_\_\_\_

**Water Well Contractor's Certification:**

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

NAME Cyril Vandehey  
(Person, firm or corporation) (Type or print)

Address Rt. 2, Box 262, Forest Grove

Drilling Machine Operator's License No. 42

[Signed] Cyril Vandehey  
(Water Well Contractor)

Contractor's License No. 353 Date 12-13, 1965