NOTICE TO WATER WELL CONTRACTOR
The original and first copy of this report are to be filed with the STATE ENGINEER, SALEM, OREGON 97310 within 30 days from the date of well completion.

RECEIVED MAR 12 1969 STATE ENGINEER SALEM, OREGON

WATER WELL REPORT
STATE OF OREGON
(Please type or print) (Do not write above this line)

WASH 6099

State Well No. 1N/3W-11

State Permit No. WIDL 98574

Amended 3/30/2026

(1) OWNER:
Name Roth Developement Corp.
Address 1500 N.E. 25 th. Hillsboro,Ore.

(2) TYPE OF WORK (check):
New Well [X] Deepening [ ] Reconditioning [ ] Abandon [ ]
If abandonment, describe material and procedure in Item 12.

(3) TYPE OF WELL:
Rotary [ ] Driven [ ]
Cable [X] Jetted [ ]
Dug [ ] Bored [ ]

(4) PROPOSED USE (check):
Domestic [X] Industrial [ ] Municipal [ ]
Irrigation [ ] Test Well [ ] Other [ ]

(5) CASING INSTALLED:
Threaded [ ] Welded [X]
" Diam. from ft. to ft. Gage
6 " Diam. from 0 ft. to 552'11" ft. Gage 17#
" Diam. from ft. to ft. Gage

PERFORATIONS:
Perforated? [ ] Yes [X] No.
Type of perforator used
Size of perforations in. by in.
perforations from ft. to ft.
perforations from ft. to ft.
perforations from ft. to ft.
perforations from ft. to ft.
perforations from ft. to ft.

(7) SCREENS:
Well screen installed? [ ] Yes [X] No
Manufacturer's Name
Type Model No.
Diam. Slot size Set from ft. to ft.
Diam. Slot size Set from ft. to ft.

(8) WATER LEVEL: Completed well.
Static level 37 ft. below land surface Date 3/6/69
Artesian pressure lbs. per square inch Date

(9) WELL TESTS:
Drawdown is amount water level is lowered below static level
Was a pump test made? [ ] Yes [X] No If yes, by whom?
Yield: gal./min. with ft. drawdown after hrs.
" " " "
" " " "
Bailer test 40 gal./min. with 160 ft. drawdown after 1 hrs.
Artesian flow g.p.m. Date
Temperature of water Norm Was a chemical analysis made? [ ] Yes [X] No

(10) CONSTRUCTION:
Well seal—Material used Bentonite & puddled clay
Depth of seal 22 ft.
Diameter of well bore to bottom of seal 10 in.
Were any loose strata cemented off? [ ] Yes [X] No Depth
Was a drive shoe used? [X] Yes [ ] No
Did any strata contain unusable water? [X] Yes [ ] No
Type of water? Wet depth of strata 7 ft.
Method of sealing strata off drove pipe past
Was well gravel packed? [ ] Yes [X] No Size of gravel:
Gravel placed from ft. to ft.

(11) LOCATION OF WELL:
County Wash Driller's well number
¼ ¼ Section 11 T. 1 N R. 3 W W.M.
Bearing and distance from section or subdivision corner
32905 NW BEACH RD, HILLSBORO, OR 97124 45.59037380
TL 2200 -123.01539480

(12) WELL LOG:
Diameter of well below casing 6
Depth drilled 702 ft. Depth of completed well 700 ft.

Formation: Describe color, texture, grain size and structure of materials; and show thickness and nature of each stratum and aquifer penetrated, with at least one entry for each change of formation. Report each change in position of Static Water Level as drilling proceeds. Note drilling rates.

MATERIAL	From	To	SWL
brown clay & sandy clay	0	18	
blue clay	18	63	
brown clay	63	111	27
grey "	111	120	
brown "	120	180	
brown " & fine sand	180	230	
red sandy clay	230	287	
blue sand w/ water 916 gal	287	295	30
blue clay	295	310	
brown "	310	330	
blue sand w/water & clay	330	360	
fine blue sand w/ water	360	380	
blue & grey gritty clau	380	440	
brown clay w/ wood	440	505	
red clay	505	547	
med rock	547	590	
soft "	590	700	
hard "	700	702	37

Work started Dec 15 1968 Completed Mar.6 1969
Date well drilling machine moved off of well Mar 7 1969

Drilling Machine Operator's Certification:
This well was constructed under my direct supervision. Materials used and information reported above are true to my best knowledge and belief.
[Signed] Stan Gaunt (Drilling Machine Operator) Date Mar 6, 1969
Drilling Machine Operator's License No. 216

Water Well Contractor's Certification:
This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.
NAME A.J. Gaunt (Person, firm or corporation) (Type or print)
Address Aloha,Ore.
[Signed] A.J. Gaunt (Water Well Contractor)
Contractor's License No. 4 Date Mar 6, 1969

(USE ADDITIONAL SHEETS IF NECESSARY)