

NOTICE TO WATER WELL CONTRACTOR  
The original and first copy  
of this report are to be  
filed with the

STATE ENGINEER, SALEM, OREGON 97310  
within 30 days from the date  
of well completion.

WASH  
6312

WATER WELL REPORT RECEIVED  
STATE OF OREGON  
(Please type or print) SEP 5 1974  
(Do not write above this line) STATE ENGINEER

State Well No. 1N/3W-25  
State Permit No. \_\_\_\_\_

(1) OWNER:

Name Columbia Pacific Council-Boy Scouts of  
Address 2145 S.W. Front Avenue America  
Portland, Oregon

(2) TYPE OF WORK (check):

New Well  Deepening  Reconditioning  Abandon   
If abandonment, describe material and procedure in Item 12.

(3) TYPE OF WELL:

Rotary  Driven   
Cable  Jetted   
Dug  Bored

(4) PROPOSED USE (check):

Domestic  Industrial  Municipal   
Irrigation  Test Well  Other

CASING INSTALLED:

Threaded  Welded   
" Diam. from + 10" ft. to 16'9" ft. Gage .250  
5-9/16" Diam. from 40 ft. to 60 ft. Gage .188  
" Diam. from \_\_\_\_\_ ft. to \_\_\_\_\_ ft. Gage \_\_\_\_\_

PERFORATIONS:

Perforated?  Yes  No.

Type of perforator used Torch  
Size of perforations 1/8 in. by 12 in.  
12 perforations from 145 ft. to 159 ft.  
perforations from \_\_\_\_\_ ft. to \_\_\_\_\_ ft.  
perforations from \_\_\_\_\_ ft. to \_\_\_\_\_ ft.

(7) SCREENS:

Well screen installed?  Yes  No

Manufacturer's Name \_\_\_\_\_  
Type \_\_\_\_\_ Model No. \_\_\_\_\_  
Diam. \_\_\_\_\_ Slot size \_\_\_\_\_ Set from \_\_\_\_\_ ft. to \_\_\_\_\_ ft.  
Diam. \_\_\_\_\_ Slot size \_\_\_\_\_ Set from \_\_\_\_\_ ft. to \_\_\_\_\_ ft.

(8) WELL TESTS:

Drawdown is amount water level is lowered below static level

Was a pump test made?  Yes  No If yes, by whom?  
Yield: \_\_\_\_\_ gal./min. with \_\_\_\_\_ ft. drawdown after \_\_\_\_\_ hrs.  
" " " "  
" " " "  
Bailer test 3 gal./min. with 22 ft. drawdown after 2 hrs.  
Artesian flow \_\_\_\_\_ g.p.m.

(9) CONSTRUCTION:

Well seal—Material used Bentonite  
Well sealed from land surface to 18 ft.  
Diameter of well bore to bottom of seal 10 in.  
Diameter of well bore below seal 6 in.  
Number of sacks of cement used in well seal 0 sacks  
Number of sacks of bentonite used in well seal 2 sacks  
Brand name of bentonite International Gel  
Number of pounds of bentonite per 100 gallons  
of water 50 lbs./100 gals.  
Was a drive shoe used?  Yes  No Plugs \_\_\_\_\_ Size: location \_\_\_\_\_ ft.  
Did any strata contain unusable water?  Yes  No  
Type of water? \_\_\_\_\_ depth of strata \_\_\_\_\_  
Method of sealing strata off \_\_\_\_\_  
Was well gravel packed?  Yes  No Size of gravel: \_\_\_\_\_  
Gravel placed from \_\_\_\_\_ ft. to \_\_\_\_\_ ft.

(10) LOCATION OF WELL:

County Washington Driller's well number \_\_\_\_\_  
1/4 1/4 Section 25 T. 1 N. R. 3 W. W.M.  
Bearing and distance from section or subdivision corner \_\_\_\_\_

(11) WATER LEVEL: Completed well.

Depth at which water was first found 54 ft.  
Static level 15 ft. below land surface. Date 5/7/74  
Artesian pressure \_\_\_\_\_ lbs. per square inch. Date \_\_\_\_\_

(12) WELL LOG:

Diameter of well below casing 6"  
Depth drilled 60 ft. Depth of completed well 60 ft.

Formation: Describe color, texture, grain size and structure of materials; and show thickness and nature of each stratum and aquifer penetrated, with at least one entry for each change of formation. Report each change in position of Static Water Level and indicate principal water-bearing strata.

MATERIAL	From	To	SWL
Topsoil	0	2	
Soft brown silty clay	2	31	
Soft gray clay w/some sand particles	31	54	
Soft gray silty clay	54	60	

Work started 5/2/74 19 Completed 5/7/74 19  
Date well drilling machine moved off of well 5/7/74 19

Drilling Machine Operator's Certification:  
This well was constructed under my direct supervision. Materials used and information reported above are true to my best knowledge and belief.  
[Signed] [Signature] Date 5/8/74, 19\_\_\_\_  
(Drilling Machine Operator)  
Drilling Machine Operator's License No. 751

Water Well Contractor's Certification:  
This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.  
Name A. M. Janssen Drilling Co. (Type or print)  
(Person, firm or corporation)  
Address 21075 S. W. Tualatin Valley Hwy.  
Clatsop, Oregon  
[Signed] [Signature] (Water Well Contractor)  
Contractor's License No. 79 Date 5/8/74, 19\_\_\_\_