NOTICE TO WATER WELL CONTRACTOR The original and first copy of this report are to be filed with the

## WATER WELL REPORT

WATER RESOURCES DEPARTMENT ETCE IVE TATE OF OREGON SALEM, OREGON 973 K ECE IVE (Please type or print) within 30 days from the date of well completion. JUN 2 3 1977

(Do not write above this line)



State Well No.

State Permit No. G-7792

(1) OWNER: WATER RESOURCES DEPT.	(10) LOCATION OF WELL:	
Name Otis Barby SALEM. CREGON	County Washington Driller's well number	
Address Rte 2 Box 325 Space 10 Cornelius,	1/4 1/4 Section 25 T. 1-S R. 3-W W.M.	
Oregon@xx 97113	Bearing and distance from section or subdivision corner	
(2) TYPE OF WORK (check):		
New Well 🛱 Deepening 🗌 Reconditioning 🗎 Abandon 🗍		
If abandonment, describe material and procedure in Item 12.	(11) WATER LEVEL: Completed well.	
(3) TYPE OF WELL: (4) PROPOSED USE (check):		
Rotary K Driven Domestic K Industrial Municipal	Static level 120 ft. below land surface. Date 692977	
Cable   Jetted		0-2-77
Dug   Bored   Irrigation   Test Well   Other	Artesian pressure lbs. per squar	e inch. Date
CASING INSTALLED: Threaded □ Welded №  6 "Diam. from □ ft. to 52 ft. Gage •250  "Diam. from ft. to ft. Gage PERFORATIONS: Perforated? □ Ves. □ No.	(12) WELL LOG: Diameter of well below casing 6  Depth drilled 335 ft. Depth of completed well 335 ft.  Formation: Describe color, texture, grain size and structure of materials; and show thickness and nature of each stratum and aquifer penetrated, with at least one entry for each change of formation. Report each change in position of Static Water Level and indicate principal water-bearing strata.	
1 C1101 CCC.   1 CD   25110.		
Type of perforator used	MATERIAL	From To SWL
Size of perforations in. by in.	Top soil	0 1-1/2
perforations from	Brown clay	1-1/2 12
perforations from	Brown clay and boulders	12   35   35   46
perforations from ft. to ft.	Brown sandstone Brown rock	46 50
(7) SCREENS: Well screen installed? ☐ Yes 译 No	Blue basalt	50 85
Manufacturer's Name	Black lava rock	85 95
Type Model No	Blue basalt	95 120
Diam Slot size Set from ft. to ft.	Brown rock	120 140
Diam. Slot size Set from ft. to ft.	Blue basalt	140 175
(8) WELL TESTS: Drawdown is amount water level is	Black lava rock	175 190
lowered below static level	Blue basalt	190   270
Was a pump test made? ☐ Yes ☐ No If yes, by whom?	Brown rock	270 305
Yield: gal./min. with ft. drawdown after hrs.	Black alva rock	305 325
" " "	Brown rock	<b>3</b> 25 335
äir " "	The state of the s	
Ratler test 35 gal./min. with 195 ft. drawdown after 1 hrs.		
Artesian flow g.p.m.		
perature of water Depth artesian flow encountered ft.	Work started 6-1-77 19 Complete	ed 6-2-77 19
(9) CONSTRUCTION:	Date well drilling machine moved off of well	6-2-77 19
Well seal—Material used Coment	Drilling Machine Operator's Certification:	
Well sealed from land surface to	This well was constructed under my direct supervision.	
Diameter of well bore to bottom of seal in.	Materials used and information reported above are true to my best knowledge and belief.	
Diameter of well bore below seal6 in.	and an analysis ( 9 777	
Number of sacks of cement used in well seal8	(DrMing Machine Operator)	
How was cement grout placed?	Drilling Machine Operator's License No. 254	
pumped	Water Well Contractor's Certification:	
	This well was drilled under my jurisdiction and this report is	
Was a drive shoe used? ☐ Yes 🗗 No Plugs Size: location ft.	true to the best of my knowledge and belief.	
Did any strata contain unusable water? 🗌 Yes 💆 No	Name Ralph Turner Drilling Co. (Type or print)	
Type of water? depth of strata	Address Rte 1 Box 141 Hillsboro, Oregon 9712	
Method of sealing strata off		
Was well gravel packed? ☐ Yes 🖫 No Size of gravel:	[Signed] (Water Well Contractor)	
Gravel placed from ft. to ft.	Contractor's License No. 247 Date 6	
Let		····· 10