

The original and first copy
of this report are to be
filed with the

RECEIVED
FEB 3 1966
OREGON 97310
DATE
STATE ENGINEER

STATE ENGINEER, SALEM, OREGON 97310
within 30 days from the date
of well completion.

STATE OF OREGON
(Please type or print)

State Well No. 1N/3W-33

State Permit No. _____

Name Walter Duyck
Address 5635 S W 145 Beaverton

County Washington Driller's well number _____
 _____ 1/4 _____ 1/4 Section 33 T. 1 N R. 3 W W.M.
 Bearing and distance from section or subdivision corner _____

Drilling Well ☒ Deepening ☐ Reconditioning ☐ Abandon ☐
 If abandonment, describe material and procedure in Item 12.

Domestic ☒ Industrial ☐ Municipal ☐
Irrigation ☐ Test Well ☐ Other ☐

Rotary	<input type="checkbox"/>	Driven	<input type="checkbox"/>
Cable	<input checked="" type="checkbox"/>	Jettied	<input type="checkbox"/>
Dug	<input type="checkbox"/>	Bored	<input type="checkbox"/>

Threaded ☐ Welded ☒

6" Diam. from 0 ft. to 157' 3" ft. Gage $\frac{1}{4}$
 " Diam. from ft. to ft. Gage
 " Diam. from ft. to ft. Gage

Perforated? ☐ Yes ☒ No

Type of perforator used

Size of perforations	in. by	in.
perforations from	ft. to	ft.
perforations from	ft. to	ft.
perforations from	ft. to	ft.
perforations from	ft. to	ft.
perforations from	ft. to	ft.

Well screen installed? ☐ Yes ☒ No

Manufacturer's Name _____
 _____ Model No. _____
 Diam. _____ Slot size _____ Set from _____ ft. to _____ ft.
 Diam. _____ Slot size _____ Set from _____ ft. to _____ ft.

Well seal—Material used in seal Bentonite

Depth of seal 19 ft. Was a packer used? no

Diameter of well bore to bottom of seal 11 in.

Were any loose strata cemented off? ☐ Yes ☒ No Depth _____

Was a drive shoe used? ☒ Yes ☐ No

Was well gravel packed? ☐ Yes ☒ No Size of gravel: _____

Gravel placed from _____ ft. to _____ ft.

Did any strata contain unusuable water? ☐ Yes ☒ No

Type of water? _____ depth of strata _____

Method of sealing strata off _____

Static level 20 ft. below land surface Date 1-28-66
Artesian pressure _____ lbs. per square inch Date _____

Drawdown is amount water level is lowered below static level

Was a pump test made? ☐ Yes ☒ No If yes, by whom?

Yield:	gal./min. with	ft. drawdown after	hrs.
"	"	"	"
"	"	"	"

Bailer test 20 gal./min. with 40 ft. drawdown after 1 hrs.

[illegible]

Temperature of water 54 Was a chemical analysis made? ☐ Yes ☒ No

Diameter of well below casing 6"

Depth drilled 170 ft. Depth of completed well 170 ft.

Formation: Describe by color, character, size of material and structure, and show thickness of aquifers and the kind and nature of the material in each stratum penetrated, with at least one entry for each change of formation.

[illegible]

Work started	1-20	1966	Completed	1-28	1966
Date well drilling machine moved off of well	1-28	1966			

Manufacturer's Name none

Type: H.P.

Water Well Contractor's Certification:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

NAME Cyril Vandehey
(Person, firm or corporation) (Type or print)

Address Rt. 2, Box 262, Forest Grove

Drilling Machine Operator's License No. 42

[Signed] Cyril Van derhey
(Water Well Contractor)

Contractor's License No. 353 Date 1-30, 1966