

The original and first copy  
of this report are to be  
filed with the

STATE ENGINEER, SALEM, OREGON 97310  
within 30 days from the date  
of well completion. STA

**RECEIVED**  
MAY 15 1970  
STATE ENGINEER  
SALEM, OREGON

# WATER WELL REPORT

STATE OF OREGON

70 (Please type or print)  
(Do not write above this line)

State Well No. IN/4W-10

State Permit No. ....

Name	Milton J. Clinton
Address	Rt. 1, Box 340, Forest Grove, Oregon

New Well ☐ Deepening ☒ Reconditioning ☐ Abandon ☐  
If abandonment, describe material and procedure in Item 12.

Rotary	<input checked="" type="checkbox"/>	Driven	<input type="checkbox"/>
Cable	<input type="checkbox"/>	Jetted	<input type="checkbox"/>
Dug	<input type="checkbox"/>	Bored	<input type="checkbox"/>

Domestic ☐ Industrial ☐ Municipal ☐  
Irrigation ☒ Test Well ☐ Other ☐

Threaded ☐ Welded ☐

" Diam. from   X   ft. to   X   ft. Gage   X    
 " Diam. from   X   ft. to   X   ft. Gage   X    
 " Diam. from   X   ft. to   X   ft. Gage   X  

Perforated? ☐ Yes ☒ No.

Type of perforator used

Size of perforations	in. by	in.
perforations from	ft. to	ft.
perforations from	ft. to	ft.
perforations from	ft. to	ft.
perforations from	ft. to	ft.
perforations from	ft. to	ft.

Well screen installed? ☐ Yes ☐ No

Manufacturer's Name .....

Type ..... Model No. ....

Diam. .... Slot size ..... Set from ..... ft. to ..... ft.

Diam. .... Slot size ..... Set from ..... ft. to ..... ft.

Static level	ft. below land surface	Date
Artesian pressure	ONE lbs. per square inch	5/12/70

**Drawdown is amount water level is lowered below static level**

Was a pump test made? ☐ Yes ☒ No If yes, by whom?

Yield:	gal./min. with	ft. drawdown after	hrs.
	"	"	"

**AIRLIFT**  
Bailer test **155** gal./min. with **300** ft. drawdown after **2** hrs.  
Artesian flow **5** g.d.m. Date **4/12/70**

Temperature of water      Was a chemical analysis made? ☐ Yes ☒ No

Well seal—Material used X

Depth of seal X ft.

Diameter of well bore to bottom of seal X in.

Were any loose strata cemented off? ☒ Yes ☐ No Depth X

Was a drive shoe used? ☒ Yes ☐ No

Did any strata contain unusable water? ☒ Yes ☐ No

Type of water? X depth of strata X

Method of sealing strata off X

Was well gravel packed? ☐ Yes ☐ No ☒ Size of gravel: X

Gravel placed from X ft. to X ft.

County Washington Driller's well number \_\_\_\_\_  
 1/4 1/4 Section 10 T. 1 N R. E 4 W. W.M.  
 Bearing and distance from section or subdivision corner \_\_\_\_\_

465-492 7-7/8" 492-520 6-3/4"  
Diameter of well below casing

Depth drilled 55 ft. Depth of completed well 520 ft.

Formation: Describe color, texture, grain size and structure of materials; and show thickness and nature of each stratum and aquifer penetrated, with at least one entry for each change of formation. Report each change in position of Static Water Level as drilling proceeds. Note drilling rates.

[illegible]

Work started 3/24/70 19 Completed 4/12/70 19

Date well drilling machine moved off of well 4/12/70 19

### Drilling Machine Operator's Certification:

This well was constructed under my direct supervision. Materials used and information reported above are true to my best knowledge and belief.

[Signed] Hollis E. Brunkenkamp Date 4/12/70, 1970  
(Drilling Machine Operator)

Drilling Machine Operator's License No. 235

**Water Well Contractor's Certification:**

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

NAME A. M. Jannsen Drilling Co.  
(Person, firm or corporation) (Type or print)

Address 21075 S.W. Tualatin Valley Hwy, Aloha, Ore

[Signed] Edwa. A. Jensen  
(Water Well Contractor)

Contractor's License No. 79 Date 5/12/70 19