

NOTICE TO WATER WELL CONTRACTOR

The original and first copy of this report are to be filed with the

STATE ENGINEER, SALEM, OREGON within 30 days from the date of well completion.

WASH 6686

WATER WELL REPORT

RECEIVED RECEIVED STATE OF OREGON SEP 26 1968 OCT 28 1968

State Well No. 1N/4W-14

State Permit No.

STATE ENGINEER STATE ENGINEER SALEM, OREGON

(1) OWNER:

Name Kenneth Willis Address Route 1 Box 296 Forest Grove, Oregon

(1) LOCATION OF WELL:

County Washington Driller's well number 1/4 Section 14 T. 1N R. 4W W.M.

(2) TYPE OF WORK (check):

New Well [ ] Deepening [x] Reconditioning [ ] Abandon [ ] If abandonment, describe material and procedure in Item 12.

(3) TYPE OF WELL:

Rotary [ ] Driven [ ] Cable [x] Jetted [ ] Dug [ ] Bored [ ]

(4) PROPOSED USE (check):

Domestic [x] Industrial [ ] Municipal [ ] Irrigation [x] Test Well [ ] Other [ ]

(5) CASING INSTALLED:

6" Diam. from 0 ft. to 490 ft. Gage 3/4 4 1/2" Diam. from 485 ft. to 565 ft. Gage 3/16

(12) WELL LOG:

Diameter of well below casing 6" Depth drilled 25 ft. Depth of completed well 565 ft.

Formation: Describe color, texture, grain size and structure of materials; and show thickness and nature of each stratum and aquifer penetrated, with at least one entry for each change of formation. Report each change in position of Static Water Level as drilling proceeds. Note drilling rates.

Table with columns: MATERIAL, From, To, SWL. Row 1: Rock Soft, 539, 565.

(6) PERFORATIONS:

Perforated? [x] Yes [ ] No. Type of perforator used Cut With Titch Size of perforations 1 1/2 in. by 1 1/2 in. Number of perforations from 485 ft. to 565 ft. 50

(7) SCREENS:

Well screen installed? [ ] Yes [x] No Manufacturer's Name Type Model No. Diam. Slot size Set from ft. to Diam. Slot size Set from ft. to

(8) WATER LEVEL: Completed well.

Static level ft. below land surface Date Artesian pressure 14 lbs. per square inch Date 9-18-68

(9) WELL TESTS:

Drawdown is amount water level is lowered below static level Was a pump test made? [ ] Yes [x] No If yes, by whom? Y gal./min. with ft. drawdown after hrs. Bailer test gal./min. with ft. drawdown after hrs. Artesian flow 85 g.p.m. Date Temperature of water 50 Was a chemical analysis made? [ ] Yes [x] No

(10) CONSTRUCTION:

Well seal—Material used Depth of seal Diameter of well bore to bottom of seal in. Were any loose strata cemented off? [ ] Yes [ ] No Depth 18 Was a drive shoe used? [ ] Yes [ ] No Did any strata contain unusable water? [ ] Yes [ ] No Type of water? depth of strata Method of sealing strata off Was well gravel packed? [ ] Yes [x] No Size of gravel: Gravel placed from ft. to ft.

Drilling Machine Operator's Certification:

This well was constructed under my direct supervision. Materials used and information reported above are true to my best knowledge and belief.

[Signed] Cyril Van Dehey 9-18-68 (Drilling Machine Operator)

Drilling Machine Operator's License No. 42

Water Well Contractor's Certification:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

NAME Cyril Vandehay (Person, firm or corporation) (Type or print) Address Route 2 Box 262 Forest Grove, Oregon

[Signed] Cyril Vandehay (Water Well Contractor)

Contractor's License No. 353 Date 9-18-68, 19