

NOTICE TO WATER WELL CONTRACTOR

The original and first copy of this report are to be filed with the

STATE ENGINEER, SALEM, OREGON 97310 within 30 days from the date of well completion.

RECEIVED **RECEIVED** **WASH 6688**
WATER WELL REPORT SEP 14 1967
 STATE ENGINEER OF OREGON STATE ENGINEER
 SALEM, ORE. (Please type or print) SALEM, OREGON
 State Well No. 1N/4w-14
 State Permit No. _____

(1) OWNER:

Name Melvin Love
 Address Rt. 1, Forest Grove, Oregon

(2) TYPE OF WORK (check):

New Well Deepening Reconditioning Abandon
 If abandonment, describe material and procedure in Item 12.

(3) TYPE OF WELL:

Rotary Driven
 Cable Jetted
 Dug Bored

(4) PROPOSED USE (check):

Domestic Industrial Municipal
 Irrigation Test Well Other

CASING INSTALLED:

Threaded Welded
6" Diam. from 0 ft. to 417 ft. Gage 1/4
 " Diam. from _____ ft. to _____ ft. Gage _____
 " Diam. from _____ ft. to _____ ft. Gage _____

PERFORATIONS:

Perforated? Yes No.

Type of perforator used _____

Size of perforations	in.	by	in.
perforations from _____	ft.	to _____	ft.
perforations from _____	ft.	to _____	ft.
perforations from _____	ft.	to _____	ft.
perforations from _____	ft.	to _____	ft.
perforations from _____	ft.	to _____	ft.

(7) SCREENS:

Well screen installed? Yes No

Manufacturer's Name _____
 Type _____ Model No. _____
 Diam. _____ Slot size _____ Set from _____ ft. to _____ ft.
 Diam. _____ Slot size _____ Set from _____ ft. to _____ ft.

(8) WATER LEVEL: Completed well.

Static level _____ ft. below land surface Date _____
 Man pressure 35 lbs. per square inch Date 8/15/67

(9) WELL TESTS:

Drawdown is amount water level is lowered below static level

Was a pump test made? Yes No If yes, by whom?
 Yield: _____ gal./min. with _____ ft. drawdown after _____ hrs.
 " " " " " "
 " " " " " "
 Bailer test _____ gal./min. with _____ ft. drawdown after _____ hrs.
 Artesian flow 12 g.p.m. Date 8/15/67
 Temperature of water 54 Was a chemical analysis made? Yes No

(10) CONSTRUCTION:

Well seal—Material used Bentanite
 Depth of seal 18 ft.
 Diameter of well bore to bottom of seal 10 in.
 Were any loose strata cemented off? Yes No Depth _____
 Was a drive shoe used? Yes No
 Did any strata contain unusable water? Yes No
 Type of water? _____ depth of strata _____
 Method of sealing strata off _____
 Was well gravel packed? Yes No Size of gravel: _____
 Gravel placed from _____ ft. to _____ ft.

(11) LOCATION OF WELL:

County Washington Driller's well number _____
 1/4 1/4 Section 14 T. 1N R. 4W W.M.
 Bearing and distance from section or subdivision corner _____

(12) WELL LOG:

Diameter of well below casing 6"

Depth drilled 500 ft. Depth of completed well 500 ft.

Formation: Describe color, texture, grain size and structure of materials; and show thickness and nature of each stratum and aquifer penetrated, with at least one entry for each change of formation. Report each change in position of Static Water Level as drilling proceeds. Note drilling rates.

MATERIAL	From	To	SWL
Brown Silty	0	10	
Brown Clay	10	25	
Blue Quick Sand	25	65	
Gray Clay Soft	65	80	
Wood in Quick Sand	80	120	
Blue Clay and Fine Sand	120	220	
Blue Clay	220	230	
Brown Clay	230	245	
Blue Clay	245	320	
Red Rock and Gravel	320	340	
Red Clay Soft	340	410	
Red Rock Soft	410	500	

Work started 7/29 1967 Completed 8/15 1967

Date well drilling machine moved off of well 8/15 1967

Drilling Machine Operator's Certification:

This well was constructed under my direct supervision. Materials used and information reported above are true to my best knowledge and belief.

[Signed] Cyril Vandehey Date 8/16, 1967
 (Drilling Machine Operator)

Drilling Machine Operator's License No. 42

Water Well Contractor's Certification:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

NAME Cyril Vandehey
 (Person, firm or corporation) (Type or print)

Address Rt. 2, Box 262 Forest Grove, Oregon

[Signed] Cyril Vandehey
 (Water Well Contractor)

Contractor's License No. 353 Date 8/16, 1967