

NOTICE TO WATER WELL CONTRACTOR
 The original and first copy
 of this report are to be
 filed with the
 STATE ENGINEER, SALEM, OREGON 97310
 within 30 days from the date
 of well completion.

RECEIVED
APR 17 1967
STATE ENGINEER
OREGON

WATER WELL REPORT
 (Please type or print)

WASH
 0689

State Well No. W/4w-14
 State Permit No. _____

(1) OWNER:

Name Ernest Heesacker
 Address Rt. 1, Box 363
Forest Grove, Oregon

(2) LOCATION OF WELL:

County Washington Driller's well number _____
 1/4 Section 14 T. 1 N R. 4 W W.M.
 Bearing and distance from section or subdivision corner _____

(3) TYPE OF WORK (check):

New Well Deepening Reconditioning Abandon
 If abandonment, describe material and procedure in Item 12.

(4) PROPOSED USE (check):

Domestic Industrial Municipal Rotary Driven
 Irrigation Test Well Other Cable Jetted
 Dug Bored

(6) CASING INSTALLED:

Threaded Welded
 6" Diam. from 0 ft. to 447 ft. Gage 1/4
 " Diam. from ft. to ft. Gage
 " Diam. from ft. to ft. Gage

(7) PERFORATIONS:

Perforated? Yes No
 Type of perforator used _____
 Size of perforations in. by in.
 perforations from ft. to ft.
 perforations from ft. to ft.
 perforations from ft. to ft.
 perforations from ft. to ft.
 perforations from ft. to ft.

(8) SCREENS:

Well screen installed? Yes No
 Manufacturer's Name _____
 Model No. _____
 Diam. Slot size Set from ft. to ft.
 Diam. Slot size Set from ft. to ft.

(9) CONSTRUCTION:

Well seal—Material used in seal Bentanite
 Depth of seal 18 ft. Was a packer used? _____
 Diameter of well bore to bottom of seal 10 in.
 Were any loose strata cemented off? Yes No Depth _____
 Was a drive shoe used? Yes No
 Was well gravel packed? Yes No Size of gravel: _____
 Gravel placed from ft. to ft.
 Did any strata contain unusable water? Yes No
 Type of water _____ depth of strata _____
 Method of sealing strata off _____

(10) WATER LEVELS:

Static level _____ ft. below land surface Date _____
 Artesian pressure 35 lbs. per square inch Date 4/8/67

(11) WELL TESTS:

Drawdown is amount water level is lowered below static level
 Was a pump test made? Yes No If yes, by whom?
 Yield: gal./min. with ft. drawdown after hrs.
 " " " "
 " " " "
 Bailer test gal./min. with ft. drawdown after hrs.
 Artesian flow 11 g.p.m. Date 4/8/67
 Temperature of water 52 Was a chemical analysis made? Yes No

(12) WELL LOG:

Diameter of well below casing 6"
 Depth drilled 481 ft. Depth of completed well 481 ft.
 Formation: Describe by color, character, size of material and structure, and show thickness of aquifers and the kind and nature of the material in each stratum penetrated, with at least one entry for each change of formation.

MATERIAL	FROM	TO
Brown Silty	0	25
Quick Sand	25	35
Clay Red	35	100
Quick Sand Blue	100	120
Clay Soft Blue	120	160
Clay Soft Brown	160	200
Clay Soft Red	200	380
Clay Soft Brown	380	441
Rock Soft	441	471
Rock Hard	471	481

Work started 3/18 19 67 Completed 4/8 19 67
 Date well drilling machine moved off of well _____ 19 _____

(13) PUMP:

Manufacturer's Name _____
 Type: _____ H.P. _____

Water Well Contractor's Certification:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

NAME Cyril Vandehey
 (Person, firm or corporation) (Type or print)
 Address Rt. 2, Box 262 Forest Grove, Ore.
 Drilling Machine Operator's License No. 42
 [Signed] Cyril Vandehey
 (Water Well Contractor)
 Contractor's License No. 353 Date 4/9 19 67