

NOTICE TO WATER WELL CONTRACTOR

The original and first copy of this report are to be filed with the

STATE ENGINEER, SALEM, OREGON 97310 within 30 days from the date of well completion.

RECEIVED
STATE OF OREGON
 WATER WELL REPORT
 (Please type or print)
 (Do not write above this line)
STATE ENGINEER
OREGON

WASH
6700

State Well No. 1N/4W-14M
 State Permit No. _____

G-4535

(1) OWNER:

Name Kenneth Willis
 Address Rt. 1, Box 296 Forest Grove, Ore.

(2) TYPE OF WORK (check):

New Well Deepening Reconditioning Abandon

If abandonment, describe material and procedure in Item 12.

(3) TYPE OF WELL:

Rotary Driven
 Cable Jetted
 Dug Bored

(4) PROPOSED USE (check):

Domestic Industrial Municipal
 Irrigation Test Well Other

CASING INSTALLED:

Threaded Welded
 6" Diam. from 0 ft. to 460 ft. Gage 1 1/4
 " Diam. from _____ ft. to _____ ft. Gage _____
 " Diam. from _____ ft. to _____ ft. Gage _____

PERFORATIONS:

Perforated? Yes No.

Type of perforator used _____
 Size of perforations in. by in.
 _____ perforations from _____ ft. to _____ ft.
 _____ perforations from _____ ft. to _____ ft.
 _____ perforations from _____ ft. to _____ ft.
 _____ perforations from _____ ft. to _____ ft.
 _____ perforations from _____ ft. to _____ ft.

(7) SCREENS:

Well screen installed? Yes No

Manufacturer's Name _____
 Type _____ Model No. _____
 Diam. _____ Slot size _____ Set from _____ ft. to _____ ft.
 Diam. _____ Slot size _____ Set from _____ ft. to _____ ft.

(8) WATER LEVEL: Completed well.

Static level _____ ft. below land surface Date _____
 Artesian pressure 20 lbs. per square inch Date 9/29/67

(9) WELL TESTS:

Drawdown is amount water level is lowered below static level

Was a pump test made? Yes No If yes, by whom?
 Yield: gal./min. with ft. drawdown after hrs.
 " " " " "
 " " " " "
 Baller test gal./min. with ft. drawdown after hrs.
 Artesian flow 42 g.p.m. Date 9/29/67
 Temperature of water 50 Was a chemical analysis made? Yes No

(10) CONSTRUCTION:

Well seal—Material used Bentanite
 Depth of seal 18 ft.
 Diameter of well bore to bottom of seal 11 in.
 Were any loose strata cemented off? Yes No Depth _____
 Was a drive shoe used? Yes No
 Did any strata contain unusable water? Yes No
 Type of water? _____ depth of strata _____
 Method of sealing strata off _____
 Was well gravel packed? Yes No Size of gravel: _____
 Gravel placed from _____ ft. to _____ ft.

(11) LOCATION OF WELL:

County Washington Driller's well number _____
 1/4 Section 14 T. 1N R. 4W W.M.
 Bearing and distance from section or subdivision corner _____

(12) WELL LOG:

Diameter of well below casing 6"

Depth drilled 539 ft. Depth of completed well 539 ft.

Formation: Describe color, texture, grain size and structure of materials; and show thickness and nature of each stratum and aquifer penetrated, with at least one entry for each change of formation. Report each change in position of Static Water Level as drilling proceeds. Note drilling rates.

MATERIAL	From	To	SWL
Brown Silty	0	30	
Shot Soil Red	30	70	
Soft Clay Red	70	100	
Soft Clay Gray	100	120	
Soft Clay Red	120	420	
Clay Block	420	425	
Clay Red	425	455	
Rock Soft	455	539	

Work started 9/14 19 67 Completed 9/29 19 67
 Date well drilling machine moved off of well 9/29 19 67

Drilling Machine Operator's Certification:

This well was constructed under my direct supervision. Materials used and information reported above are true to my best knowledge and belief.

[Signed] Cyril Vandehy Date 10/3, 1967.
 (Drilling Machine Operator)

Drilling Machine Operator's License No. 42

Water Well Contractor's Certification:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

NAME Cyril Vandehy
 (Person, firm or corporation) (Type or print)

Address Rt. 2, Box 262 Forest Grove, Oregon

[Signed] Cyril Vandehy
 (Water Well Contractor)

Contractor's License No. 353 Date 9/29, 1967.