

NOTICE TO WATER WELL CONTRACTOR
The original and first copy
of this report are to be
filed with the

STATE ENGINEER, SALEM, OREGON 97310
within 30 days from the date
of well completion.

WATER WELL REPORT

STATE OF OREGON
(Please type or print)

STATE ENGINEER
SALEM, OREGON

RECEIVED

FEB 15 1974

State Well No.

20/2W-20

State Permit No.

WASH
6976

(1) OWNER:

Name C. M. Dupree
Address Rte 3 Box 450 Hillsboro, Oregon

(2) TYPE OF WORK (check):

New Well Deepening Reconditioning Abandon
If abandonment, describe material and procedure in Item 12.

(3) TYPE OF WELL:

Rotary Driven
Cable Jetted
Dug Bored

(4) PROPOSED USE (check):

Domestic Industrial Municipal
Irrigation Test Well Other

CASING INSTALLED:

Threaded Welded

6" Diam. from 0 ft. to 42 ft. Gage 4 wall
5-9/16" Diam. from 35 ft. to 145 ft. Gage 10 gage

PERFORATIONS:

Perforated? Yes No.

Type of perforator used torch
Size of perforations 1/8 in. by 6 in.
22 perforations from 125 ft. to 145 ft.

(7) SCREENS:

Well screen installed? Yes No

Manufacturer's Name
Type Model No.
Diam. Slot size Set from ft. to ft.
Diam. Slot size Set from ft. to ft.

(8) WELL TESTS:

Drawdown is amount water level is lowered below static level

Was a pump test made? Yes No If yes, by whom?
Yield: gal./min. with ft. drawdown after hrs.
" " " " "
" " " " "
air
Boiler test 3-1/2 gal./min. with 20 ft. drawdown after 1 hrs.
Artesian flow g.p.m.

(9) CONSTRUCTION:

Well seal—Material used Bentonite
Well sealed from land surface to 42 ft.
Diameter of well bore to bottom of seal 9 in.
Diameter of well bore below seal 6 in.
Number of sacks of cement used in well seal sacks
Number of sacks of bentonite used in well seal 2 sacks
Brand name of bentonite National
Number of pounds of bentonite per 100 gallons
of water 50 lbs./100 gals.
Was a drive shoe used? Yes No Plugs Size: location ft.
Did any strata contain unusable water? Yes No
Type of water? depth of strata
Method of sealing strata off
Was well gravel packed? Yes No Size of gravel:
Gravel placed from ft. to ft.

(10) LOCATION OF WELL:

County Washington Driller's well number
1/4 1/4 Section 20 T. 2-N R. 2-W W.M.
Bearing and distance from section or subdivision corner

(11) WATER LEVEL: Completed well.

Depth at which water was first found 25 trace ft.
Static level 115 ft. below land surface. Date 2-8-74
Artesian pressure lbs. per square inch. Date

(12) WELL LOG:

Diameter of well below casing 6
Depth drilled 145 ft. Depth of completed well 145 ft.

Formation: Describe color, texture, grain size and structure of materials; and show thickness and nature of each stratum and aquifer penetrated, with at least one entry for each change of formation. Report each change in position of Static Water Level and indicate principal water-bearing strata.

MATERIAL	From	To	SWL
Top soil	0	3	
Brown clay	3	12	
Red clay	12	25	
Yellow sandy clay	25	96	
Brown sandstone	96	138	
Brown soft rock	138	145	

Work started 2-8-74 19 Completed 2-8-74 19
Date well drilling machine moved off of well 2-8-74 19

Drilling Machine Operator's Certification:

This well was constructed under my direct supervision. Materials used and information reported above are true to my best knowledge and belief.

[Signed] Ralph Turner Date 2-12-74
(Drilling Machine Operator)

Drilling Machine Operator's License No. 254

Water Well Contractor's Certification:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

Name Ralph Turner Drilling Co. (Type or print)
(Person, firm or corporation)

Address Rte 1 Box 141 Hillsboro, Oregon

[Signed] Ralph Turner
(Water Well Contractor)

Contractor's License No. 247 Date 2-12-74, 19.....