

RECEIVED

111 Wash

25/1W-28ac

STATE OF OREGON WATER WELL REPORT (as required by ORS 537.700) WATER RESOURCES DEPT SALEM, OREGON AUG 19 1985 PLEASE TYPE or PRINT IN INK

(for official use only)

(1) OWNER:

Name Joseph A Galbreath Address 19935 S.W. City Cipole Rd Sherwood State Ore

(2) TYPE OF WORK (check):

New Well [x] Deepening [] Reconditioning [] Abandon []

(3) TYPE OF WELL: (4) PROPOSED USE (check):

Rotary Air [] Driven [] Domestic [x] Industrial [] Municipal [] Thermal: Rotary Mud [] Dug [] Irrigation [] Withdrawal [] ReInjection [] Other: Cable [x] Bored [] Piezometric [] Grounding [] Test []

(5) CASING INSTALLED:

Steel [] Plastic [] Threaded [] Welded [x] 6" Diam. from +1 ft. to 215 ft. Gauge 250

LINER INSTALLED:

Steel [] Plastic [x] Threaded [] Welded [] 4" Diam. from 205 ft. to 265 ft. Gauge 160

(6) PERFORATIONS:

Perforated? [] Yes [] No Size of perforations in. by in. perforations from ft. to ft.

(7) SCREENS:

Well screen installed? [] Yes [x] No Manufacturer's Name Type Model No. Diam. Slot Size Set from ft. to ft.

(8) WELL TESTS:

Drawdown is amount water level is lowered below static level Was a pump test made? [] Yes [x] No If yes, by whom? Yield: gal./min. with ft. drawdown after hrs.

(9) CONSTRUCTION:

Special standards: Yes [] No [x] Well seal—Material used Portland Cement Well sealed from land surface to 20 ft. Diameter of well bore to bottom of seal 20 in. Diameter of well bore below seal 6 in. Amount of sealing material Six sacks [x] pounds [] How was cement grout placed? Mixed and filled from bottom to top Was pump installed? NO Type HP Depth ft. Was a drive shoe used? [x] Yes [] No Plugs Size: location ft. Did any strata contain unusable water? [] Yes [x] No Type of Water? depth of strata Method of sealing strata off Was well gravel packed? [] Yes [x] No Size of gravel: Gravel placed from ft. to ft.

(10) LOCATION OF WELL by legal description:

County Washington Sec 1/4 NE 1/4 of Section 28 Township 2 S Range 1 W WM. (Township is North or South) (Range is East or West) Tax Lot Lot Block Subdivision MAILING ADDRESS OF WELL (or nearest address)

(11) WATER LEVEL of COMPLETED WELL:

Depth at which water was first found 250 ft. Static level 30 ft. below land surface. Date 7-17-1985 Artesian pressure lbs. per square inch. Date

(12) WELL LOG:

Diameter of well below casing 6 inch Depth drilled 265 ft. Depth of completed well 265 ft. Formation: Describe color, texture, grain size and structure of materials; and show thickness and nature of each stratum and aquifer penetrated, with at least one entry for each change of formation. Report each change in position of Static Water Level and indicate principal water-bearing strata.

Table with columns: MATERIAL, From, To, SWL. Rows include: Top Soil (0-5), Clay Brown (5-40), Sand Brown (40-55), Clay Brown (55-70), Clay Blue (70-95), Sand Clay & Fine Gravel (95-110), Clay Brown (110-135), Clay Gray (135-164), Clay Brown (164-200), Coarse Sandstone (200-215), Medium Conglomerate (215-230), Clay Brown (230-235), Medium Conglomerate (235-255), Coarse Sand (255-265) 30

Date work started 7-3-1985 / completed 7-18-1985 Date well drilling machine moved off of well 7-19 1985

(unbonded) Water Well Constructor Certification (if applicable):

This well was constructed under my direct supervision. Materials used and information reported above are true to my best knowledge and belief.

[Signed] Date , 19

(bonded) Water Well Constructor Certification:

Bond # 306419 Issued by: Ohio Casualty Insurance (number) (Surety Company Name) On behalf of John Reiser (type or print name of Water Well Constructor)

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief:

(Signed) John Reiser (Water Well Constructor) (Dated) 7-18-1985