NOTICE TO WATER WELL CONTRACTOR
The original and first copy of this report are to be filed with the

STATE ENGINEER, SALEM, OREGON 97310 within 30 days from the date of well completion.

WAS 7194

WATER WELL REPORT

STATE OF OREGON

(Please type or print)

(Do not write above this line)

RECEIVED
JUL 24 1975
WATER RESOURCES DEPT.
SALEM, OREGON

State Well No. 2N/2W-34Cc

State Permit No. G-2669

App. # G-8285

(1) OWNER:

Name ~~xxxxxx~~ Bob Yungen

Address Rte 1 Box 129 Hillsboro, Oregon

(2) TYPE OF WORK (check):

New Well ~~XX~~ X Deepening ☐ Reconditioning ☐ Abandon ☐

If abandonment, describe material and procedure in Item 12.

(3) TYPE OF WELL:

Rotary ☒ Driven ☐
Cable ☐ Jetted ☐
Dug ☐ Bored ☐

(4) PROPOSED USE (check):

Domestic ☒ Industrial ☐ Municipal ☐
Irrigation ☐ Test Well ☐ Other ☐

(5) CASING INSTALLED:

Threaded ☐ Welded ☒

6 " Diam. from 0 ft. to 144 ft. Gage .280

" Diam. from ft. to ft. Gage

" Diam. from ft. to ft. Gage

(6) PERFORATIONS:

Perforated? ☐ Yes ☒ No.

Type of perforator used

Size of perforations in. by in.

perforations from ft. to ft.

perforations from ft. to ft.

perforations from ft. to ft.

(7) SCREENS:

Well screen installed? ☐ Yes ~~XX~~ ☐ No

Manufacturer's Name

Type Model No.

Diam. Slot size Set from ft. to ft.

Diam. Slot size Set from ft. to ft.

(8) WELL TESTS:

Drawdown is amount water level is lowered below static level

Was a pump test made? ☐ Yes ☒ No If yes, by whom?

Yield: gal./min. with ft. drawdown after hrs.

" " " "

"air " " "

~~XXXXX~~ test 25 gal./min. with 225 ft. drawdown after 1 hrs.

Artesian flow g.p.m.

Temperature of water Depth artesian flow encountered ft.

(9) CONSTRUCTION:

Well seal—Material used Cement

Well sealed from land surface to 144 ft.

Diameter of well bore to bottom of seal 9 in.

Diameter of well bore below seal 6 in.

Number of sacks of cement used in well seal 14 sacks

Number of sacks of bentonite used in well seal sacks

Brand name of bentonite

Number of pounds of bentonite per 100 gallons of water lbs./100 gals.

Was a drive shoe used? ☐ Yes ☒ No Plugs Size: location ft.

Did any strata contain unusable water? ☐ Yes ☒ No

Type of water? depth of strata

Method of sealing strata off

Was well gravel packed? ☐ Yes ☒ No Size of gravel:

Gravel placed from ft. to ft.

(10) LOCATION OF WELL:

County Washington Driller's well number

¼ ¼ Section 34 T. 2-N R. 2-W W.M.

Bearing and distance from section or subdivision corner

(11) WATER LEVEL: Completed well.

Depth at which water was first found 75 trace ft.

Static level 120 ft. below land surface. Date 7-18-75

Artesian pressure lbs. per square inch. Date

(12) WELL LOG:

Diameter of well below casing 6

Depth drilled 365 ft. Depth of completed well 365 ft.

Formation: Describe color, texture, grain size and structure of materials; and show thickness and nature of each stratum and aquifer penetrated, with at least one entry for each change of formation. *Report each change in position of Static Water Level and indicate principal water-bearing strata.*

MATERIAL	From	To	SWL
Top soil	0	3	
Brown clay	3	19	
Red clay	19	65	
Brown sandy clay	65	134	
Blue med. rock	134	168	
Brown lava rock	168	178	
Blue med. rock	178	245	
Black lava rock	245	260	
Blue med. rock	260	305	
Blue hard rock	305	325	
Black lava rock	325	342	
Blue hard rock	342	365	

Work started 7-17-75 19 Completed 7-18-75 19

Date well drilling machine moved off of well 7-18-75 19

Drilling Machine Operator's Certification:

This well was constructed under my direct supervision. Materials used and information reported above are true to my best knowledge and belief.

[Signed] Ralph Turner Date 7-19-75 19

(Drilling Machine Operator)

Drilling Machine Operator's License No. 254

Water Well Contractor's Certification:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

Name Ralph Turner Drilling Co

(Person, firm or corporation) (Type or print)

Address Rte 1 Box 141 Hillsboro, Oregon

[Signed] Ralph Turner

(Water Well Contractor)

Contractor's License No. 247 Date 7-19-75, 19

(USE ADDITIONAL SHEETS IF NECESSARY)

SP*45656-119