

ICE TO WATER WELL CONTRACTOR

The original and first copy of this report are to be filed with the

STATE ENGINEER, SALEM, OREGON 97310 within 30 days from the date of well completion.

RECEIVED WATER WELL REPORT OCT 27 1966 STATE OF OREGON (Please type or print) STATE ENGINEER

RECEIVED OCT 27 1966 STATE OF OREGON (Please type or print) STATE ENGINEER

WASH 8123 2N/4W-27N

(1) OWNER:

Name FERD NARUP Address STAR RT. BANKS, ORE.

(2) LOCATION OF WELL:

County Washington Driller's well number 1/4 Section 27 T. 2N R. 4W W.M. Bearing and distance from section or subdivision corner

(3) TYPE OF WORK (check):

New Well X Deepening Reconditioning Abandonment

(4) PROPOSED USE (check):

Domestic Industrial Municipal Irrigation X Test Well Other

(5) TYPE OF WELL:

Rotary Driven Cable X Jetted Dug Bored

(6) CASING INSTALLED:

Threaded Welded X 6" Diam. from 0 ft. to 70 ft. Gage 250

(7) PERFORATIONS:

Perforated? X Yes No Type of perforator used TORCH Size of perforations 1/4 in. by 12 in. 25 perforations from 55 ft. to 70 ft.

(8) SCREENS:

Well screen installed? X Yes No Manufacturer's Name Model No. Diam. Slot size Set from ft. to ft.

(9) CONSTRUCTION:

Well seal—Material used in seal BENTONITE 100# Depth of seal 18 ft. Was a packer used? Yes Diameter of well bore to bottom of seal 10 in. Were any loose strata cemented off? X No Depth Was a drive shoe used? X No Was well gravel packed? X No Size of gravel: Gravel placed from ft. to ft. Did any strata contain unusable water? X No Type of water depth of strata Method of sealing strata off

(10) WATER LEVELS:

Static level 5 1/2 ft. below land surface Date 9/21/66 Artesian pressure lbs. per square inch Date

(11) WELL TESTS:

Drawdown is amount water level is lowered below static level Was a pump test made? Yield: gal./min. with ft. drawdown after hrs. Bailer test 30 gal./min. with 6 ft. drawdown after 1 hrs. Artesian flow g.p.m. Date Temperature of water NCRM as a chemical analysis made? X No

(12) WELL LOG:

Diameter of well below casing Depth drilled 70 ft. Depth of completed well 70 ft. Formation: Describe by color, character, size of material and structure, and show thickness of aquifers and the kind and nature of the material in each stratum penetrated, with at least one entry for each change of formation.

Table with columns MATERIAL, FROM, TO. Rows: CLAY BROWN 0 8, RED 8 24, YELLOW 24 43, SAND STONE AND GRAVEL GREY 43 52, YELLOW 52 70

Work started 9/20 1966 Completed 9/20 1966 Date well drilling machine moved off of well 9/21 1966

(13) PUMP:

Manufacturer's Name ? Type: ? H.P.

Water Well Contractor's Certification:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

NAME FELIX DEVLAMINCK (Person, firm or corporation) (Type or print)

Address Rt. Box 310 CORNELIUS, ORE

Drilling Machine Operator's License No. 17

[Signed] Felix Devlaminck (Water Well Contractor)

Contractor's License No. 197 Date 9/26 1966