NOTICE TO WATER WELL CONTRACTOR
The original and first copy of this report are to be filed with the
WATER RESOURCES DEPARTMENT,
SALEM, OREGON 97310
within 30 days from the date of well completion.

WASH 8310

WATER WELL REPORT
STATE OF OREGON
(Please type or print)
(Do not write above this line)

RECEIVED DEC 16 1977 WATER RESOURCES DEPT. SALEM, OREGON

State Well No. 2N/5W-22ba
State Permit No.

(1) OWNER:
Name Diabetic Asst. of Oregon (Childs Camp)
Address Glenwood Dr.

(2) TYPE OF WORK (check):
New Well ☑ Deepening ☐ Reconditioning ☐ Abandon ☐
If abandonment, describe material and procedure in Item 12.

(3) TYPE OF WELL:
Rotary ☑ Driven ☐
Cable ☐ Jetted ☐
Dug ☐ Bored ☐

(4) PROPOSED USE (check):
Domestic ☑ Industrial ☐ Municipal ☐
Irrigation ☐ Test Well ☐ Other ☐

CASING INSTALLED: Threaded ☐ Welded ☑
6" Diam. from 0 ft. to 20 ft. Gage .250
5" Diam. from 15 ft. to 105 ft. Gage .188
" Diam. from ft. to ft. Gage

PERFORATIONS: Perforated? ☑ Yes ☐ No.
Type of perforator used Torch
Size of perforations 3/4 in. by 2 in.
15 perforations from 30 ft. to 90 ft.
perforations from ft. to ft.
perforations from ft. to ft.

(7) SCREENS: Well screen installed? ☐ Yes ☑ No
Manufacturer's Name
Type Model No.
Diam. Slot size Set from ft. to ft.
Diam. Slot size Set from ft. to ft.

(8) WELL TESTS: Drawdown is amount water level is lowered below static level
Was a pump test made? ☐ Yes ☑ No If yes, by whom?
Yield: gal./min. with ft. drawdown after hrs.
" " " "
" " " "
Bailer test 8 gal./min. with 70 ft. drawdown after 1 hrs.
Artesian flow g.p.m.
Temperature of water 53 Depth artesian flow encountered ft.

(9) CONSTRUCTION:
Well seal—Material used Cement
Well sealed from land surface to 18 ft.
Diameter of well bore to bottom of seal 10 in.
Diameter of well bore below seal 6 in.
Number of sacks of cement used in well seal 14 sacks
How was cement grout placed? Poured
Was a drive shoe used? ☐ Yes ☑ No Plugs Size: location ft.
Did any strata contain unusable water? ☐ Yes ☑ No
Type of water? depth of strata
Method of sealing strata off
Was well gravel packed? ☐ Yes ☑ No Size of gravel:
Gravel placed from ft. to ft.

(10) LOCATION OF WELL:
County Wash Driller's well number
NE ¼ NW ¼ Section 22 T. 2 R. 5 W.M.
Bearing and distance from section or subdivision corner

(11) WATER LEVEL: Completed well.
Depth at which water was first found 75 ft.
Static level 8 ft. below land surface. Date 12-7-77
Artesian pressure lbs. per square inch. Date

(12) WELL LOG: Diameter of well below casing 6
Depth drilled 105 ft. Depth of completed well 105 ft.
Formation: Describe color, texture, grain size and structure of materials; and show thickness and nature of each stratum and aquifer penetrated, with at least one entry for each change of formation. Report each change in position of Static Water Level and indicate principal water-bearing strata.

MATERIAL	From	To	SWL
Brn soil	0	2	
Brn clay	2	8	
Brn clay small boulders	8	12	
Hard blue Claystone	12	75	
Blue Claystone-thin layers Rock	75	105	8

Work started 12-7 1977 Completed 12-7 1977
Date well drilling machine moved off of well 12-7 1977

Drilling Machine Operator's Certification:
This well was constructed under my direct supervision. Materials used and information reported above are true to my best knowledge and belief.
[Signed] Joseph Trussell (Drilling Machine Operator) Date 12-7, 1977
Drilling Machine Operator's License No. 832

Water Well Contractor's Certification:
This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.
Name Dra Trussell (Person, firm or corporation) (Type or print)
Address 2 Manning Ore
[Signed] Dra Trussell (Water Well Contractor)
Contractor's License No. 472 Date 12-7, 1977

(USE ADDITIONAL SHEETS IF NECESSARY)

SP*45656-119