

NOTICE TO WATER WELL CONTRACTOR

The original and first copy of this report are to be filed with the

RECEIVED
MAY 20 1968
STATE ENGINEER
SALM OREGON

WATER WELL REPORT WA SH 8354

STATE ENGINEER, SALEM, OREGON 97310, within 30 days from the date of well completion

STATE OF OREGON (Please type or print) Do not write above this line

State Well No. 2N/6W-24 da

State Permit No.

(1) OWNER:

Name Oregon State Forest Serv.
Address Forest Grove Ore
Sales Creek

(2) TYPE OF WORK (check):

New Well [x] Deepening [] Reconditioning [] Abandon []

If abandonment, describe material and procedure in Item 12.

(3) TYPE OF WELL:

Rotary [] Driven []
Cable [x] Jetted []
Dug [] Bored []

(4) PROPOSED USE (check):

Domestic [] Industrial [] Municipal []
Irrigation [] Test Well [] Other [x]

CASING INSTALLED:

6" Diam. from 0 ft. to 87 ft. Gage 280
" Diam. from ft. to ft. Gage
" Diam. from ft. to ft. Gage

PERFORATIONS:

Perforated? [] Yes [x] No.
Type of perforator used
Size of perforations in. by in.
perforations from ft. to ft.
perforations from ft. to ft.
perforations from ft. to ft.
perforations from ft. to ft.
perforations from ft. to ft.

(7) SCREENS:

Well screen installed? [] Yes [x] No
Manufacturer's Name
Type Model No.
Diam. Slot size Set from ft. to ft.
Diam. Slot size Set from ft. to ft.

(8) WATER LEVEL: Completed well.

Static level 8 ft. below land surface Date 6-8-68
Artesian pressure lbs. per square inch Date

(9) WELL TESTS:

Drawdown is amount water level is lowered below static level
Was a pump test made? [] Yes [x] No If yes, by whom?
Yield: gal./min. with ft. drawdown after hrs.
Bailer test 7 gal./min. with 80 ft. drawdown after 3 hrs.
Artesian flow g.p.m. Date
Temperature of water Was a chemical analysis made? [] Yes [x] No

(10) CONSTRUCTION:

Well seal—Material used cement grout
Depth of seal 3.5 ft.
Diameter of well bore to bottom of seal 10 in.
Were any loose strata cemented off? [] Yes [x] No Depth
Was a drive shoe used? [x] Yes [] No
Did any strata contain unusable water? [] Yes [x] No
Type of water? depth of strata
Method of sealing strata off
Was well gravel packed? [] Yes [x] No Size of gravel:
Gravel placed from ft. to ft.

(11) LOCATION OF WELL:

County Washington Driller's well number 117
NE 1/4 SE 1/4 Section 24 T. 2N R. 6W W.M.
Bearing and distance from section or subdivision corner

(12) WELL LOG:

Diameter of well below casing 6"
Depth drilled 100 ft. Depth of completed well 100 ft.
Formation: Describe color, texture, grain size and structure of materials; and show thickness and nature of each stratum and aquifer penetrated, with at least one entry for each change of formation. Report each change in position of Static Water Level as drilling proceeds. Note drilling rates.

Table with 4 columns: MATERIAL, From, To, SWL. Rows include TOP SOIL, Shale, and BASALT.

Work started 11-20 1968 Completed 12-8 1968
Date well drilling machine moved off of well 12-8 1968

Drilling Machine Operator's Certification:

This well was constructed under my direct supervision. Materials used and information reported above are true to my best knowledge and belief.
[Signed] Robert Schelbund Date 3-21, 1969
(Drilling Machine Operator)
Drilling Machine Operator's License No. 337

Water Well Contractor's Certification:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.
NAME Blue Water Drilling Co.
(Person, firm or corporation) (Type or print)
Address RT 1 BX 75 Dayton, Ore.
[Signed] Robert Schelbund
(Water Well Contractor)
Contractor's License No. 417 Date 3-21, 1969