NOTICE TO WATER WELL CONTRACTOR
The original and first copy
of this report are to be
filed with the The original and first copy
of this report are to be
filed with the

STATE OF OREGON JAN251974 State Well No. 15 1W-30 (Please type or print STATE FLOW)

STATE ENGINEER, SALEM OREGON 97310 within 30 days from the date of well completion.

(Please type or print STATE ENGINEER (Do not write above this SALEM, OREGON

2000	.,		
State	Permit	No.	

(1) OWNER:	(10) LOCATION OF WELL:			
Name C. V. Morrison	County Washington Driller's well number			
Address 8600 S. W. 170th Avenue	SW 14 NE 14 Section 30 T. 1 S	R. 1 W.	W.M.	
Beaverton, Oregon 97005	Bearing and distance from section or subdivisi			
(2) TYPE OF WORK (check):	2501115 and diseased from Section of Subdivisi	on corner		
New Well ☐ Deepening ☑ Reconditioning ☐ Abandon ☐				
If abandonment, describe material and procedure in Item 12.	(11) YELAMININ T TAYLOR O 1 . 1	11	<del></del>	
(3) TYPE OF WELL: (4) PROPOSED USE (check):	(11) WATER LEVEL: Completed w			
Rotory W Driven D		325	ft.	
Cable	Static level 286 ft. below land s	surface. Date	1/18/74	
Dug Bored I Irrigation Test Well Other	Artesian pressure lbs. per squar	e inch. Date		
CASING INSTALLED: Threaded □ Welded □  "Diam. from X ft. to X ft. Gage  "PERFORATIONS: Perforated? □ Yes X No.	(12) WELL LOG: Diameter of well below casing 6tt  Depth drilled 80 ft. Depth of completed well 385 ft.  Formation: Describe color, texture, grain size and structure of materials; and show thickness and nature of each stratum and aquifer penetrated, with at least one entry for each change of formation. Report each change in position of Static Water Level and indicate principal water-bearing strata.			
Type of perforator used	MATERIAL	From To	SWL	
Size of perforations in. by in.	Previously drilled	0 305	dry	
ft. to ft.	Hard brown basalt	305 320		
perforations from ft. to ft.	Broken gray-black basalt	320 325		
perforations from ft. to ft.	Broken b rown & Black basalt	325 345	2 gpm	
(7) SCREENS: Well screen installed? I Ves X No.	Fractured black basalt-hard	345 360		
, on boreat material. I to 45 140	Broken brown & black basalt-			
Manufacturer's Name	perforated w/multi-colored			
Type Model No.	rock seams	360 380	18 gpm	
Diam.         Slot size         Set from         ft. to         ft.           Diam.         Slot size         Set from         ft. to         ft.	Hard gray-black basalt	380 385		
(8) WELL TESTS: Drawdown is amount water level is lowered below static level Was a pump test made?   Yes X No If yes, by whom?	-			
Yield: gal./min. with ft. drawdown after hrs.				
" " "				
" " " "				
airlift oo 71.	<u>.</u> .			
Artesian flow g.p.m.	***			
derature of water Depth artesian flow encountered ft.	Work started $1/17/7$ 4 19 Complete		19	
(9) CONSTRUCTION:	Date well drilling machine moved off of well	1/18/74	19	
Well seal—Material usedX	Drilling Machine Operator's Certification:			
Well sealed from land surface to the seal seal seal seaks.  Diameter of well bore to bottom of seal in.  Diameter of well bore below seal in.  Number of sacks of cement used in well seal sacks.  Number of sacks of bentonite used in well seal sacks.	This well was constructed under my Materials used and information reported best knowledge and belief.  [Signed]	above are tru  Date 1/22/7	e to my 1, 19	
Brand name of bentonite X	Water Well Contractor's Certification:			
Number of pounds of bentonite per 100 gallions of water lbs./100 gals.	This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.			
Was a drive shoe used?  Yes No Plugs X Size: location ft.	Name A. M. Jannsen Drilling Co.			
Did any strata contain unusable water? Tyes No	(Person, firm or corporation) (Type or print) Address 21075 S.W. Tualatin Valley Hwy, Aloha, Or.			
Type of water? depth of strata	Address 210/5 8. W. Iualatin Vali	Ley nwy , All	Olla, Ore	
Method of sealing strata off  Wes well gravel packed?   Ves   New Size of American	[Signed Liver W. M.	axell		
Was well gravel packed?  Yes  No Size of gravel:	(Water Well Contra	-		
Gravel placed fromft. toft.	Contractor's License No79 Date	1/22/74	, 19	