

NOTICE TO WATER WELL CONTRACTOR: The original and first copy of this report are to be filed with the

STATE ENGINEER, SALEM, OREGON 97310 within 30 days from the date of well completion.

RECEIVED JUL 13 1972 WATER WELL REPORT WASH STATE OF OREGON (Please type or print) SALEM, OREGON (Do not write above this line) 009419

State Well No. 15/2W-3 State Permit No.

(1) OWNER:

Name Bill Sanders Address 23450 S. W. Lois Beaverton, Oregon 97005

(2) TYPE OF WELL (check):

New Well [x] Deepening [] Reconditioning [] Abandon [] If abandonment, describe material and procedure in Item 12.

(3) TYPE OF WELL:

Rotary [] Driven [] Cable [x] Jetted [] Dug [] Bored []

(4) PROPOSED USE (check):

Domestic [x] Industrial [] Municipal [] Irrigation [] Test Well [] Other []

(5) CASING INSTALLED:

6" Diam. from 0 ft. to 101 ft. Gage 250 5-9/16" Diam. from 97 ft. to 117 ft. Gage 125

(6) PERFORATIONS:

Type of perforator used Torch Size of perforations 1/4 in. by 12 in. 48 perforations from 100 ft. to 116 ft.

(7) SCREENS:

Well screen installed? [] Yes [x] No Manufacturer's Name Type Model No. Diam. Slot size Set from ft. to ft.

(8) WELL TESTS:

Drawdown is amount water level is lowered below static level Was a pump test made? [] Yes [x] No If yes, by whom? Yield: gal./min. with ft. drawdown after hrs. Bailer test 12 gal./min. with 20 ft. drawdown after 2 hrs. Artesian flow g.p.m. Temperature of water Depth artesian flow encountered ft.

(9) CONSTRUCTION:

Well seal—Material used Bentonite Well sealed from land surface to 35 ft. Diameter of well bore to bottom of seal 10 in. Diameter of well bore below seal 6 in. Number of sacks of cement used in well seal 0 sacks Number of sacks of bentonite used in well seal 3 sacks Brand name of bentonite SDG 330 Number of pounds of bentonite per 100 gallons of water 50 lbs./100 gals. Was a drive shoe used? [x] Yes [] No Plugs Size: location ft. Did any strata contain unusable water? [] Yes [x] No Type of water? depth of strata Method of sealing strata off Was well gravel packed? [] Yes [x] No Size of gravel: Gravel placed from ft. to ft.

(10) LOCATION OF WELL:

County Washington Driller's well number 1/4 Section 3 T. 1 S R. 2 W. W.M. Bearing and distance from section or subdivision corner

(11) WATER LEVEL: Completed well.

Depth at which water was first found 99 ft. Static level 30 ft. below land surface. Date 6/29/72 Artesian pressure lbs. per square inch. Date

(12) WELL LOG:

Diameter of well below casing 6" Depth drilled 117 ft. Depth of completed well 117 ft.

Formation: Describe color, texture, grain size and structure of materials; and show thickness and nature of each stratum and aquifer penetrated, with at least one entry for each change of formation. Report each change in position of Static Water Level and indicate principal water-bearing strata.

Table with columns: MATERIAL, From, To, SWL. Rows include Top soil, Brown silty clay, Blue-gray silty clay, Blue-gray clay, Blue-gray clay w/black sand streaks.

Work started 6/22/72 19 Completed 6/29/72 19 Date well drilling machine moved off of well 6/29/72 19

Drilling Machine Operator's Certification:

This well was constructed under my direct supervision. Materials used and information reported above are true to my best knowledge and belief. [Signed] Date 7/7/72, 19. Drilling Machine Operator's License No. 751

Water Well Contractor's Certification:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Name A. M. Janssen Drilling Co. Address 21075 S.W. Tualatin Valley Hwy, Aloha, Ore. [Signed] Date 7/7/72, 19. Contractor's License No. 79