

RECEIVED

WASH

NOTICE TO WATER WELL CONTRACTOR: The original and first copy of this report are to be filed with the STATE ENGINEER, SALEM 10, OREGON within 30 days from the date of well completion.

APR 17 1964

WATER WELL REPORT

009575

STATE OF OREGON (Please type or print)

State Well No. 12W-65 State Permit No.

(1) OWNER: Name Oregon Rose Tree Dry Tool Co Address 1170 East IV Hwy Hillsboro Ore

(2) LOCATION OF WELL: County Wash Driller's well number NE 1/4 SE 1/4 Section 6 T. 15 S. R. 2 W. W.M. Bearing and distance from section or subdivision corner

(3) TYPE OF WORK (check): New Well [x] Deepening [ ] Reconditioning [ ] Abandon [ ] If abandonment, describe material and procedure in item 12.

(4) PROPOSED USE (check): Domestic [ ] Industrial [ ] Municipal [ ] Irrigation [x] Test Well [ ] Other [ ] (5) TYPE OF WELL: Rotary [ ] Cable [ ] Dug [x] Driven [ ] Jetted [ ] Bored [x]

(6) CASING INSTALLED: 6" Diam. from 0 ft. to 40 ft. Gage 4"

(7) PERFORATIONS: Perforated? [ ] Yes [x] No Type of perforator used Size of perforations in. by in.

(8) SCREENS: Well screen installed? [ ] Yes [x] No Manufacturer's Name Model No. Diam. Slot size Set from ft. to ft.

(9) CONSTRUCTION: Well seal—Material used in seal Bentonite 2 off Depth of seal 20 ft. Was a packer used? yes Diameter of well bore to bottom of seal 9 in. Were any loose strata cemented off? [ ] Yes [x] No Depth Was a drive shoe used? [ ] Yes [x] No Was well gravel packed? [ ] Yes [x] No Size of gravel: Gravel placed from ft. to ft. Did any strata contain unusable water? [ ] Yes [x] No Type of water? Depth of strata Method of sealing strata off

(10) WATER LEVELS: Static level 10 ft. below land surface Date Artesian pressure lbs. per square inch Date

(11) WELL TESTS: Drawdown is amount water level is lowered below static level Was a pump test made? [x] Yes [ ] No If yes, by whom? Yield: 16 gal./min. with ft. drawdown after hrs.

(12) WELL LOG: Diameter of well below casing 3 ft. Depth drilled 40 ft. Depth of completed well 43 ft. Formation: Describe by color, character, size of material and structure, and show thickness of aquifers and the kind and nature of the material in each stratum penetrated, with at least one entry for each change of formation.

Table with columns: MATERIAL, FROM, TO. Entries include: good black soil (0-4 ft), brown clay (4-16 ft), grey sand (16-20 ft), thin layer grey Denver sand (20-22 ft), more sand (22-30 ft), thin layer brown clay (30-32 ft), blue sand (32-34 ft), blue clay heavy (34-40 ft), black sand (40-43 ft).

Work started Apr 15 1964 Completed Apr 16 1964 Date well drilling machine moved off of well Apr 16 1964

(13) PUMP: Manufacturer's Name Type: H.P.

Water Well Contractor's Certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. NAME J. H. O'Neef (Person, firm or corporation) (Type or print) Address 4318 9th Hillsboro Ore Drilling Machine Operator's License No. [Signed] (Water Well Contractor) Contractor's License No. 140 Date Apr 17 1964