

WASH

RECEIVED

009657

NOTICE TO WATER WELL CONTRACTOR

The original and first copy of this report are to be filed with the

STATE ENGINEER WATER WELL REPORT

STATE ENGINEER, SALEM, OREGON 97310 within 30 days from the date of well completion.

STATE ENGINEER (Please type or print) SALEM OREGON

G-3985

State Well No. 1/2w-8 M State Permit No.

(1) OWNER: Name Glen Walters R7. box 142 Address Minister Bridge Rd Hillsboro Ore

(2) LOCATION OF WELL: County Wash. Driller's well number SW 1/4 SW 1/4 Section 5 T. 15 R. 2W M. Bearing and distance from section or subdivision corner

(3) TYPE OF WORK (check): New Well [x] Deepening [] Reconditioning [] Abandon [] Abandonment, describe material and procedure in Item 12.

(4) PROPOSED USE (check): Domestic [] Industrial [] Municipal [] Irrigation [x] Test Well [] Other [] (5) TYPE OF WELL: Rotary [] Driven [] Cable [] Jetted [] Dug [] Bored [x]

(6) CASING INSTALLED: 6" Diam. from 0 ft. to 60 ft. Gage 7 in. Threaded [] Welded [x]

(7) PERFORATIONS: Perforated? [] Yes [x] No Type of perforator used Size of perforations in. by in.

(8) SCREENS: Well screen installed? [] Yes [x] No Manufacturer's Name Model No. Diam. Slot size Set from ft. to ft.

(9) CONSTRUCTION: Well seal—Material used in seal Bentonite Depth of seal 20 ft. Was a packer used? yes Diameter of well bore to bottom of seal 9 in. Were any loose strata cemented off? [] Yes [x] No Depth Was a drive shoe used? [] Yes [x] No Was well gravel packed? [] Yes [x] No Size of gravel: Gravel placed from ft. to ft. Did any strata contain unusable water? [] Yes [] No Type of water? depth of strata Method of sealing strata off

(10) WATER LEVELS: Static level 10 ft. below land surface Date Artesian pressure lbs. per square inch Date

(11) WELL TESTS: Drawdown is amount water level is lowered below static level Was a pump test made? [x] Yes [] No If yes, by whom? Yield: 20 gal./min. with 21 ft. drawdown after 48 hrs.

(12) WELL LOG: Diameter of well below casing 3 ft. Depth drilled 60 ft. Depth of completed well 63 ft. Formation: Describe by color, character, size of material and structure, and show thickness of aquifers and the kind and nature of the material in each stratum penetrated, with at least one entry for each change of formation.

Table with columns MATERIAL, FROM, TO. Entries include: Good black soil (0-3 ft), Brown clay (3-15 ft), Grey sand (15-26 ft), Thin layer blue clay (26-30 ft), Blue sand (30-38 ft), Blue clay quite heavy (38-42 ft), Blue sand again (42-49 ft), Blue clay extra heavy (49-60 ft), Black sand (60-63 ft).

Work started July 6 1965 Completed July 8 1965 Date well drilling machine moved off of well July 8 1965

(13) PUMP: Manufacturer's Name Type: H.P.

Water Well Contractor's Certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. NAME L. H. C. Steek (Person, firm or corporation) Address 4312 1/2 Hillsboro Ave Drilling Machine Operator's License No. [Signed] Contractor's License No. 140 Date July 8-65 1965