

WASH

RECEIVED

MAR 20 1967

BN

1/2w-7R

NOTICE TO WATER WELL CONTRACTOR

The original and first copy of this report are to be filed with the

STATE ENGINEER, SALEM, OREGON 97310 within 30 days from the date of well completion.

009660

WATER WELL REPORT

STATE OF OREGON (Please type or print)

STATE ENGINEER

G-3986

State Well No.

State Permit No.

(1) OWNER:

Name Glenn Walters
Address Route 4 Box 142 Hillsboro, OR

(2) LOCATION OF WELL:

County Wash Driller's well number
SE 1/4 SE 1/4 Section 7 T. 15 R. 2 W. W.M.
Bearing and distance from section or subdivision corner

(3) TYPE OF WORK (check):

New Well [X] Deepening [] Reconditioning [] Abandon []
If abandonment, describe material and procedure in Item 12.

(4) PROPOSED USE (check):

Domestic [X] Industrial [] Municipal []
Irrigation [] Test Well [] Other []

(5) TYPE OF WELL:

Rotary [] Driven []
Cable [] Jetted []
Dug [] Bored [X]

(6) CASING INSTALLED:

6" Diam. from 0 ft. to 48 ft. Gage 4'
8" Diam. from 48 ft. to 60 ft. Gage 4'
10" Diam. from 60 ft. to 65 ft. Gage 4'

(7) PERFORATIONS:

Perforated? [] Yes [X] No
Type of perforator used
Size of perforations in. by in.
perforations from ft. to ft.

(8) SCREENS:

Well screen installed? [] Yes [X] No
Manufacturer's Name
Model No.
Diam. Slot size Set from ft. to ft.

(9) CONSTRUCTION:

Well seal—Material used in seal Bentonite
Depth of seal 18 ft. Was a packer used? yes
Diameter of well bore to bottom of seal 9 in.
Were any loose strata cemented off? [] Yes [] No
Was a drive shoe used? [] Yes [X] No
Was well gravel packed? [] Yes [X] No
Gravel placed from ft. to ft.
Did any strata contain unusable water? [] Yes [X] No
Type of water? depth of strata
Method of sealing strata off

(10) WATER LEVELS:

Static level 8 ft. below land surface Date
Artesian pressure lbs. per square inch Date

(11) WELL TESTS:

Drawdown is amount water level is lowered below static level
Was a pump test made? [X] Yes [] No
Yield: 30 gal./min. with 24 ft. drawdown after 48 hrs.
Bailer test gal./min. with ft. drawdown after hrs.
Artesian flow g.p.m. Date
Temperature of water 60 Was a chemical analysis made? [] Yes [X] No

(12) WELL LOG:

Table with columns MATERIAL, FROM, TO. Entries include: Good black soil (0-3), brown clay (3-12), yellowish sand (12-18), grey Denver mud (18-20), more sand (20-24), grey Denver mud (24-26), more sand (26-30), thin layer blue clay (30-32), blue sand (32-40), black blue clay heavy (40-48), black sand (48-50).

Wasn't enough water
Went on done
thick heavy layer blue clay 50-60 ft
some more black sand 60-65 ft

Work started Mar 1 1967 Completed Apr 10 1967
Date well drilling machine moved off of well 19

(13) PUMP:

Manufacturer's Name
Type: H.P.

Water Well Contractor's Certification:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

NAME J. H. McNeal
Address 4315 9th Hillsboro Ore
Drilling Machine Operator's License No.

[Signed] (Water Well Contractor)
Contractor's License No. 140 Date Mar 31 1967