

RECEIVED

WASH

15/2W-18dc

STATE OF OREGON WATER WELL REPORT (as required by ORS 537.765)

APR 14 1986

009990

WATER RESOURCES DEPT

(1) OWNER:

Name Oregon Berry Packing Co. Address Route 6, Box 232 City Hillsboro, Oregon State 97123 Zip

(2) TYPE OF WORK:

New Well Deepen Recondition Abandon

(3) DRILL METHOD:

Rotary Air Rotary Mud Cable Other

(4) PROPOSED USE:

Domestic Community Industrial Irrigation Thermal Injection Other

(5) BORE HOLE CONSTRUCTION:

Depth of Completed Well 74 ft.

Special Standards date of approval

Table with columns: HOLE Diameter, From, To, SEAL Material, From, To, Amount sacks or pounds. Includes entry for 6 inch diameter, 0 to 74 feet, cement seal, 20 sacks.

How was seal placed? Method A B C D E

Backfill placed from 18 ft. to 74 ft. Material 8 Aqua

(6) CASING/LINER:

Table with columns: Diameter, From, To, Gauge, Steel, Plastic, Welded, Threaded. Includes entries for 6 inch casing from 1 to 28 feet and 6 inch casing from 28 to 74 feet.

Final location of shoe(s)

(7) PERFORATIONS/SCREENS:

Perforations Method Screens Type Aardvark Material PVC

Table with columns: From, To, Slot size, Number, Diameter, Tele/pipe size, Casing, Liner. Includes entry for slot size .020 from 28 to 68 feet.

(8) WELL TESTS: Minimum testing time is 1 hour

Table with columns: Pump, Bailer, Air, Flowing, Artesian, Yield gal/min, Pumping level, Drill stem at, Time. Includes test results for 30 gal/min at 11' and 66 gal/min at 21'.

Temperature of water Depth Artesian Flow Found Was a water analysis done? Did any strata contain water not suitable for intended use? Salty Muddy Odor Colored Other

(9) LOCATION OF WELL by legal description:

County Washington Township 1 S Range 2 W Section 18 SE SW Tax Lot Lot Block Subdivision Street Address of Well (or nearest address)

(10) STATIC WATER LEVEL:

2 ft. below land surface. Date 4/8/86 Artesian pressure lb. per square inch. Date

(11) WELL LOG:

Table with columns: Material, From, To, WB?, SWL. Lists soil layers: Topsoil, Dark brown clay, Soft light brown clay, Fine gray silty clay, Soft brown silty clay, Soft gray silt w/fine sand seams & wood, Soft light gray clay, Soft gray-green sandy clay.

WELL COMPLETED TO 74 FT.

Date started 4/4/86 Completed 4/8/86

(unbonded) Water Well Constructor Certification:

I constructed this well in compliance with Oregon well construction standards. Materials used and information reported above are true to my best knowledge and belief.

Signed Date

(bonded) Water Well Constructor Certification:

I accept responsibility for construction of this well and its compliance with all Oregon water well standards. This report is true to the best of my knowledge and belief.

Signed Date

Company A. M. JANNSEN WELL DRILLING Job No.