NOTICE TO WATER WELL CONTRACTOR
The original and first copy of this report are to be filed with the STATE ENGINEER, SALEM, OREGON 97310 within 30 days from the date of well completion.

RECEIVED DEC 3 0 1973 STATE ENGINEER SALEM, OREGON

RECEIVED JAN 7 1974 STATE ENGINEER SALEM, OREGON

WATER WELL REPORT

STATE OF OREGON (Please type or print) Do not write above this line

RECEIVED AUG 20 1973 STATE ENGINEER SALEM OREGON

WHEE 157

State Well No. 8S/25E-28

State Permit No.

(1) OWNER:

Name Robert Weldon

Address Spray Ore

(2) TYPE OF WORK (check):

New Well ☑ Deepening ☐ Reconditioning ☐ Abandon ☐

If abandonment, describe material and procedure in Item 12.

(3) TYPE OF WELL:

Rotary ☑ Driven ☐
Cable ☐ Jetted ☐
Dug ☐ Bored ☐

(4) PROPOSED USE (check):

Domestic ☐ Industrial ☐ Municipal ☐
Irrigation ☑ Test Well ☐ Other ☐

(5) CASING INSTALLED:

Threaded ☐ Welded ☑

8 " Diam. from 0 ft. to 120' ft. Gage .277

" Diam. from ft. to ft. Gage

" Diam. from ft. to ft. Gage

(6) PERFORATIONS:

Perforated? ☑ Yes ☐ No

Type of perforator used Mills Knife

Size of perforations 1/2 in. by 5" in.

105 perforations from 80 ft. to 115 ft.

perforations from ft. to ft.

perforations from ft. to ft.

(7) SCREENS:

Well screen installed? ☐ Yes ☑ No

Manufacturer's Name

Type Model No.

Diam. Slot size Set from ft. to ft.

Diam. Slot size Set from ft. to ft.

(8) WELL TESTS:

Drawdown is amount water level is lowered below static level

Was a pump test made? ☑ Yes ☐ No If yes, by whom?

200 gal./min. with 105 ft. drawdown after 3 MONTHS hrs.

" " " "

" " " "

Air Baller test 150 gal./min. with 115 ft. drawdown after 1 hrs.

Artesian flow g.p.m.

Temperature of water Depth artesian flow encountered ft.

(9) CONSTRUCTION:

Well seal—Material used Clay

Well sealed from land surface to 120' ft.

Diameter of well bore to bottom of seal 8 in.

Diameter of well bore below seal 6 in.

Number of sacks of cement used in well seal 0 sacks

Number of sacks of bentonite used in well seal 0 sacks

Brand name of bentonite

Number of pounds of bentonite per 100 gallons of water lbs./100 gals.

Was a drive shoe used? ☐ Yes ☑ No Plugs Size: location ft.

Did any strata contain unusable water? ☑ Yes ☐ No

Type of water? Surface depth of strata 5-20'

Method of sealing strata off Drive Casing into Clay

Was well gravel packed? ☐ Yes ☑ No Size of gravel:

Gravel placed from ft. to ft.

(10) LOCATION OF WELL:

County Wheeler Driller's well number 20

¼ ¼ Section 28 T. 8S R. 25E W.M.

Bearing and distance from section or subdivision corner

(11) WATER LEVEL: Completed well.

Depth at which water was first found 85 ft.

Static level 5' ft. below land surface. Date 9-24-73

Artesian pressure lbs. per square inch. Date

(12) WELL LOG:

Diameter of well below casing 6

Depth drilled 165 ft. Depth of completed well 165 ft.

Formation: Describe color, texture, grain size and structure of materials; and show thickness and nature of each stratum and aquifer penetrated, with at least one entry for each change of formation. *Report each change in position of Static Water Level and indicate principal water-bearing strata.*

MATERIAL	From	To	SWL
Soil	0	4	
clay Grey	4	50	
" "	50	67	
" + Sand Grey	67	85	
Sand + Gravel	85	97	H2O
Med Sand To Coarse Gravel	97	100	H2O
Gravel Black + Grey	100	118	H2O
Clay	118	120	
Clay Grey Hard	120	130	
" Brown Hard	130	133	
" Grey "	133	165	

Work started 4-12 19 73 Completed 4-24 19 73

Date well drilling machine moved off of well 4-24 19 73

Drilling Machine Operator's Certification:

This well was constructed under my direct supervision. Materials used and information reported above are true to my best knowledge and belief.

[Signed] Van Tillyne (Drilling Machine Operator) Date 4-25-, 1973

Drilling Machine Operator's License No. 836

Water Well Contractor's Certification:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

Name Larry Burd (Person, firm or corporation) (Type or print)

Address P.O. Box 417

[Signed] Larry Burd (Water Well Contractor)

Contractor's License No. 544 Date 7-30, 1973

(USE ADDITIONAL SHEETS IF NECESSARY)

SP*45656-119