NOTICE TO WATER WELL CONTRACTOR
The original and first copy of this report are to be filed with the STATE ENGINEER, SALEM, OREGON 97310 within 30 days from the date of well completion.

RECEIVED FEB 4 1975 STATE ENGINEER SALEM, OREGON

RECEIVED MAY 22 1974 STATE ENGINEER SALEM, OREGON

WATER WELL REPORT
STATE OF OREGON

(Please type or print) (Do not write above this line)

State Well No. 7S/21E-17 (98) (da)

State Permit No.

(1) OWNER:
Name Paul W. Brown
Address Box 306 Prineville, Ore.

(2) TYPE OF WORK (check):
New Well ☒ Deepening ☐ Reconditioning ☐ Abandon ☐
If abandonment, describe material and procedure in Item 12.

(3) TYPE OF WELL:
Rotary ☐ Driven ☐
Cable ☒ Jetted ☐
Dug ☐ Bored ☐

(4) PROPOSED USE (check):
Domestic ☒ Industrial ☐ Municipal ☐
Irrigation ☐ Test Well ☐ Other ☐

CASING INSTALLED: Threaded ☐ Welded ☒
8" Diam. from +2 ft. to 40 ft. Gage 1322
" Diam. from ft. to ft. Gage
" Diam. from ft. to ft. Gage

PERFORATIONS: Perforated? ☐ Yes ☒ No.
Type of perforator used
Size of perforations in. by in.
perforations from ft. to ft.
perforations from ft. to ft.
perforations from ft. to ft.

(7) SCREENS: Well screen installed? ☐ Yes ☒ No
Manufacturer's Name
Type Model No.
Diam. Slot size Set from ft. to ft.
Diam. Slot size Set from ft. to ft.

(8) WELL TESTS: Drawdown is amount water level is lowered below static level
Was a pump test made? ☐ Yes ☒ No If yes, by whom?
Yield: gal./min. with ft. drawdown after hrs.
" " " "
" approx " " "
Bailer test 20 gal./min. with 80 ft. drawdown after 1 hrs.
Artesian flow g.p.m.
Temperature of water 53° Depth artesian flow encountered ft.

(9) CONSTRUCTION:
Well seal—Material used Neat Cement.
Well sealed from land surface to 38 ft.
Diameter of well bore to bottom of seal 16 in.
Diameter of well bore below seal 8 in.
Number of sacks of cement used in well seal 6 yards sacks
Number of sacks of bentonite used in well seal sacks
Brand name of bentonite
Number of pounds of bentonite per 100 gallons of water lbs./100 gals.
Was a drive shoe used? ☐ Yes ☒ No Plugs Size: location ft.
Did any strata contain unusable water? ☐ Yes ☒ No
Type of water? depth of strata
Method of sealing strata off
Was well gravel packed? ☐ Yes ☒ No Size of gravel:
Gravel placed from ft. to ft.

(10) LOCATION OF WELL:
County Wheeler Driller's well number
NE ¼ SE ¼ Section 17 T. 7S R. 21E W.M.
Bearing and distance from section or subdivision corner

(11) WATER LEVEL: Completed well.
Depth at which water was first found 65 ft.
Static level 35 ft. below land surface. Date 3/29-74
Artesian pressure lbs. per square inch. Date

(12) WELL LOG: Diameter of well below casing 8
Depth drilled 200 ft. Depth of completed well 200 ft.

Formation: Describe color, texture, grain size and structure of materials; and show thickness and nature of each stratum and aquifer penetrated, with at least one entry for each change of formation. *Report each change in position of Static Water Level and indicate principal water-bearing strata.*

MATERIAL	From	To	SWL
Top Soil	0	6	
Brown Clay & Boulders	6	14	
Green Claystone	14	32	
Blue-Grey Granite Decomposed	32	200	35

Work started 1/8 1974 Completed 2/2 1974
Date well drilling machine moved off of well 5/6 1974

Drilling Machine Operator's Certification:
This well was constructed under my direct supervision. Materials used and information reported above are true to my best knowledge and belief.
[Signed] [illegible] (Drilling Machine Operator) Date 5/8, 1974
Drilling Machine Operator's License No. 348

Water Well Contractor's Certification:
This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.
Name C & R Drilling Co. (Person, firm or corporation) (Type or print)
Address 1275 Madras Hwy Prineville 97754
[Signed] [illegible] (Water Well Contractor)
Contractor's License No. 540 Date 5/8, 1974

(USE ADDITIONAL SHEETS IF NECESSARY)

SP*45656-119