

NOTICE TO WATER WELL CONTRACTOR

The original and first copy of this report are to be filed with the

RECEIVED FEB 19 1971

WATER WELL REPORT

STATE OF OREGON

STATE ENGINEER, SALEM, OREGON 97310

within 30 days from the date of well completion.

STATE ENGINEER SALEM, OREGON

(Please type or print)

(Do not write above this line)

Yamh 2180

State Well No. 3/2W-8

State Permit No.

(1) OWNER:

Name North Valley Friends Church Address Rt 1, Box 151, Newberg, Ore 97132

(2) TYPE OF WORK (check):

New Well [X] Deepening [ ] Reconditioning [ ] Abandon [ ]

If abandonment, describe material and procedure in Item 12.

(3) TYPE OF WELL:

Rotary [ ] Cable [X] Dug [ ] Driven [ ] Jetted [ ] Bored [ ]

(4) PROPOSED USE (check):

Domestic [X] Industrial [ ] Municipal [ ] Irrigation [ ] Test Well [ ] Other [ ]

CASING INSTALLED:

Threaded [ ] Welded [X]

6 5/8 OD Diam. from 0 ft. to 96 ft. Gage .250

" Diam. from ft. to ft. Gage

" Diam. from ft. to ft. Gage

PERFORATIONS:

Perforated? [X] Yes [ ] No.

Type of perforator used cutting torch

Size of perforations 1/4 in. by 16 in.

24 perforations from 32 ft. to 95 ft.

perforations from ft. to ft.

perforations from ft. to ft.

(7) SCREENS:

Well screen installed? [ ] Yes [X] No

Manufacturer's Name

Type Model No.

Diam. Slot size Set from ft. to ft.

Diam. Slot size Set from ft. to ft.

(8) WELL TESTS:

Drawdown is amount water level is lowered below static level

Was a pump test made? [ ] Yes [X] No If yes, by whom?

Yield: gal./min. with ft. drawdown after hrs.

" " " "

" " " "

Bailer test 30 gal./min. with 23 ft. drawdown after 1 hrs.

Artesian flow g.p.m.

Temperature of water Depth artesian flow encountered ft.

CONSTRUCTION:

Well seal—Material used cement

Well sealed from land surface to 30 ft.

Diameter of well bore to bottom of seal 10 in.

Diameter of well bore below seal 8 in.

Number of sacks of cement used in well seal 2 sacks

Number of sacks of bentonite used in well seal 0 sacks

Brand name of bentonite

Number of pounds of bentonite per 100 gallons

of water lbs./100 gals.

Was a drive shoe used? [ ] Yes [X] No Plugs Size: location ft.

Did any strata contain unusable water? [ ] Yes [X] No

Type of water? depth of strata

Method of sealing strata off

Was well gravel packed? [X] Yes [ ] No Size of gravel: 3/8

Gravel placed from 30 ft. to 95 ft.

(10) LOCATION OF WELL:

County Yamhill Driller's well number 1/4 1/4 Section 8 T.3S R.2W W.M.

Bearing and distance from section or subdivision corner b b b

(11) WATER LEVEL: Completed well.

Depth at which water was first found 36 ft.

Static level 17 ft. below land surface. Date 2-13-71

Artesian pressure lbs. per square inch. Date

(12) WELL LOG:

Diameter of well below casing 6"

Depth drilled 120 ft. Depth of completed well 120 ft.

Formation: Describe color, texture, grain size and structure of materials; and show thickness and nature of each stratum and aquifer penetrated, with at least one entry for each change of formation. Report each change in position of Static Water Level and indicate principal water-bearing strata.

Table with 4 columns: MATERIAL, From, To, SWL. Rows include clay, broken blue shale, blue shale, blue shade first water here, broken shale water here, blue shale, light blue shale hard, blue shale some broken layers, blue shale some broken layers, blue shale small broken layers.

Work started 2-10-1971 Completed 2-13 19 71

Date well drilling machine moved off of well 2-13 19 71

Drilling Machine Operator's Certification:

This well was constructed under my direct supervision. Materials used and information reported above are true to my best knowledge and belief.

[Signed] John H. Meeker Date 2-15-71, 19 (Drilling Machine Operator)

Drilling Machine Operator's License No. 50

Water Well Contractor's Certification:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

Name JOHN MEEKER WELL DRILLING (Person, firm or corporation) (Type or print)

Address 2902 Hoover Blvd, Newberg, Ore 97132

[Signed] John H. Meeker (Water Well Contractor)

Contractor's License No. 111 Date 2-15, 19 71