

RECEIVED

Yamh
2206

NOTICE TO WATER WELL CONTRACTOR
The original and first copy of this report are to be filed with the
STATE ENGINEER, SALEM, OREGON
within 30 days from the date of well completion.

NOV 12 1965

WATER WELL REPORT

State Well No. 3/2w-8 H
State Permit No. G 3446

STATE ENGINEER SALEM OREGON
(Please type or print)

(1) OWNER:
Name Walter Kovach
Address 116 E 5th Newberg Ore

(2) LOCATION OF WELL:
County Yamhill Driller's well number
1/4 Section T. R. W.M.
Bearing and distance from section or subdivision corner
Sec 9 T 3 S R 2 W

(3) TYPE OF WORK (check):
New Well Deepening Reconditioning Abandon
Abandonment, describe material and procedure in Item 12.

(4) PROPOSED USE (check):
Domestic Industrial Municipal
Irrigation Test Well Other

(5) TYPE OF WELL:
Rotary Driven
Cable Jetted
Dug Bored

(6) CASING INSTALLED:
Threaded Welded
6" Diam. from 41 ft. to 219 ft. Gage 7
" Diam. from ft. to ft. Gage
" Diam. from ft. to ft. Gage

(7) PERFORATIONS:
Perforated? Yes No
Type of perforator used
Size of perforations in. by in.
..... perforations from ft. to ft.
..... perforations from ft. to ft.
..... perforations from ft. to ft.
..... perforations from ft. to ft.
..... perforations from ft. to ft.

(8) SCREENS:
Well screen installed? Yes No
Manufacturer's Name
Model No.
..... Slot size Set from ft. to ft.
Diam. Slot size Set from ft. to ft.

(9) CONSTRUCTION:
Well seal—Material used in seal Bentonite
Depth of seal 37 ft. Was a packer used? no
Diameter of well bore to bottom of seal 1.6 in.
Were any loose strata cemented off? Yes No Depth
Was a drive shoe used? Yes No
Was well gravel packed? Yes No Size of gravel:
Gravel placed from ft. to ft.
Did any strata contain unusable water? Yes No
Type of water? depth of strata
Method of sealing strata off

(10) WATER LEVELS:
Static level 132 ft. below land surface Date 10/17/65
Artesian pressure lbs. per square inch Date

(11) WELL TESTS: Drawdown is amount water level is lowered below static level
Was a pump test made? Yes No If yes, by whom?
Yield: gal./min. with ft. drawdown after hrs.
" " " " "
" " " " "
Bailer test 34 gal./min. with 0 ft. drawdown after 1 hrs.
Artesian flow g.p.m. Date

(12) WELL LOG: Diameter of well below casing 6
Depth drilled 275 ft. Depth of completed well 275 ft.
Formation: Describe by color, character, size of material and structure, and show thickness of aquifers and the kind and nature of the material in each stratum penetrated, with at least one entry for each change of formation.

MATERIAL	FROM	TO
<u>Top Soil</u>	<u>0</u>	<u>2</u>
<u>Brown Clay</u>	<u>2</u>	<u>37</u>
<u>Light Brown Clay</u>	<u>37</u>	<u>130</u>
<u>Broken Basalt</u>	<u>130</u>	<u>164</u>
<u>Red Soft Rock</u>	<u>164</u>	<u>170</u>
<u>Broken Basalt</u>	<u>170</u>	<u>190</u>
<u>Brown Basalt</u>	<u>190</u>	<u>275</u>

Work started 10/11 1965. Completed 10/18 1965
Date well drilling machine moved off of well 10/18 1965

(13) PUMP:
Manufacturer's Name Jacuzzi
Type: Surb H.P. 1 1/2

Water Well Contractor's Certification:
This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.
NAME Arms Drilling & Supplies
(Person, firm or corporation) (Type or print)
Address 729 N. Main Newberg Ore
Drilling Machine Operator's License No. 82
[Signed] Harlan M. Duffner
(Water Well Contractor)
Contractor's License No. 117 Date 10/20, 1965