

16

RECEIVED JUN 16 1993 WATER RESOURCES DEPT. SALEM, OREGON

YAMH 2801

4s/3w/4bc 46222

STATE OF OREGON WATER WELL REPORT (as required by ORS 537.765)

(START CARD) # 46222

(1) OWNER: Name Ken Evenstad, Address 16235 Holdridge Road, City Wayzuta, State MN, Zip 55891

(9) LOCATION OF WELL by legal description: County Yamhill, Township 4S, Range 3W, Section 4, SW 1/4 NW 1/4, Tax Lot 2002, Street Address of Well Breyman Orchards Rd.

(2) TYPE OF WORK: [X] Recondition

(3) DRILL METHOD: [X] Rotary Air

(4) PROPOSED USE: [X] Domestic

(5) BORE HOLE CONSTRUCTION: Depth of Completed Well 527 ft.

Table with columns: HOLE Diameter, SEAL Material, Amount sacks or pounds. Entry: --not changed--

How was seal placed: Method [] A [] B [] C [] D [] E

(6) CASING/LINER:

Table with columns: Diameter, From, To, Gauge, Steel, Plastic, Welded, Threaded. Casing: 6 existing, Liner: 4, 0, 527, SDR26

Final location of shoets)

(7) PERFORATIONS/SCREENS:

Table with columns: From, To, Slot size, Number, Diameter, Tele/pipe size, Casing, Liner. Perforations: 292-311, 428-507

(8) WELL TESTS: Minimum testing time is 1 hour

Table with columns: Yield gal/min, Drawdown, Drill stem at, Time. XX Pump, 9 gal/min, < 71 drawdown, 1 hr. Time

Temperature of water approx. 55° F, Depth Artesian Flow Found, Was a water analysis done? [] Yes

(10) STATIC WATER LEVEL: 447 ft. below land surface, Date 5/11/93

(11) WATER BEARING ZONES: see (10)

Table with columns: From, To, Estimated Flow Rate, SWL. Entry: see original log

(12) WELL LOG: Ground elevation approx. 825

Table with columns: Material, From, To, SWL. Content: No new drilling. We ran bit back down to 571' redrilling slough/bridge intervals then set liner. Liner stopped on a new slough/bridge at 527'. We then set pump and ran 4 hour test including potability and nitrate.

Date started 3/11/93 Completed 5/14/93

(unbonded) Water Well Constructor Certification:

I certify that the work I performed on the construction, alteration, or abandonment of this well is in compliance with Oregon well construction standards.

Signed Donald A. Davis WWC Number 1085 Date 6/11/93

(bonded) Water Well Constructor Certification:

I accept responsibility for the construction, alteration, or abandonment work performed on this well during the construction dates reported above.

Signed Stephen Schneider WWC Number 649 Date 6/11/93