NOTICE TO WATER WELL CONTRACTOR
The original and first copy of this report are to be filed with the STATE ENGINEER, SALEM, OREGON within 30 days from the date of well completion.

WATER WELL REPORT
STATE OF OREGON
(Please type or print)
(Do not write above this line)

RECEIVED
AUG 11 1977
WATER RESOURCES DEPT.
SALEM, OREGON

State Well No. 3S/3W-5
State Permit No.

(1) OWNER:
Name Camp Tilikum
Address Rt 3 Box 462
Newberg, Or 97132

(2) TYPE OF WORK (check):
New Well ☒ Deepening ☐ Reconditioning ☐ Abandon ☐
If abandonment, describe material and procedure in Item 12.

(3) TYPE OF WELL:
Rotary ☐ Driven ☐
Cable ☒ Jetted ☐
Dug ☐ Bored ☐

(4) PROPOSED USE (check):
Domestic ☒ Industrial ☐ Municipal ☐
Irrigation ☐ Test Well ☐ Other ☐

CASING INSTALLED: Threaded ☐ Welded ☒
6 5/8OC" Diam. from 0 ft. to 62 ft. Gage .2050
5" OD" Diam. from PVC -55 ft. to 300 ft. Gage 160LB
" Diam. from ft. to ft. Gage

PERFORATIONS: Perforated? ☒ Yes ☐ No.
Type of perforator used skill saw
Size of perforations 1/8 in. by 6 in.
80 perforations from 80 ft. to 296 ft.
perforations from ft. to ft.
perforations from ft. to ft.

(7) SCREENS: Well screen installed? ☐ Yes ☒ No
Manufacturer's Name
Type Model No.
Diam. Slot size Set from ft. to ft.
Diam. Slot size Set from ft. to ft.

(8) WELL TESTS: Drawdown is amount water level is lowered below static level
Was a pump test made? ☐ Yes ☒ No If yes, by whom?
Yield: gal./min. with ft. drawdown after hrs.
" " " "
" " " "
Bailer test 8 gal./min. with at bottom ft. drawdown after 1 hrs.
Artesian flow g.p.m.
Temperature of water Depth artesian flow encountered ft.

(9) CONSTRUCTION:
Well seal—Material used cement
Well sealed from land surface to 32 ft.
Diameter of well bore to bottom of seal 10 in.
Diameter of well bore below seal 8 in.
Number of sacks of cement used in well seal 5 sacks
Number of sacks of bentonite used in well seal 0 sacks
Brand name of bentonite
Number of pounds of bentonite per 100 gallons of water lbs./100 gals.
Was a drive shoe used? ☐ Yes ☒ No Plugs Size: location ft.
Did any strata contain unusable water? ☐ Yes ☒ No
Type of water? depth of strata
Method of sealing strata off
Was well gravel packed? ☐ Yes ☒ No Size of gravel:
Gravel placed from ft. to ft.

(10) LOCATION OF WELL:
County Yamhill Driller's well number
¼ ¼ Section 5 T. 3S R. 3W W.M.
Bearing and distance from section or subdivision corner BAB

(11) WATER LEVEL: Completed well.
Depth at which water was first found 95 ft.
Static level 88 ft. below land surface. Date 7-6-77
Artesian pressure lbs. per square inch. Date

(12) WELL LOG: Diameter of well below casing 6"
Depth drilled 300 ft. Depth of completed well 300 ft.
Formation: Describe color, texture, grain size and structure of materials; and show thickness and nature of each stratum and aquifer penetrated, with at least one entry for each change of formation. *Report each change in position of Static Water Level and indicate principal water-bearing strata.*

MATERIAL	From	To	SWL
top soil	0	4	
Brown clay a little sand	4	21	
blue clay & silt	21	55	
med soft sandstone	55	96	
hard shale	96	102	
med hard shale	102	130	
med sandstone	130	180	
med gray shale some broken	180	240	
layers 5 gal here			
med hard shale 8 gal to here	240	300	88ft

Work started Jun 21 1977 Completed July 6 1977
Date well drilling machine moved off of well July 7 1977

Drilling Machine Operator's Certification:
This well was constructed under my direct supervision. Materials used and information reported above are true to my best knowledge and belief.
[Signed] John H Meeker (Drilling Machine Operator) Date July 10, 1977
Drilling Machine Operator's License No. 50

Water Well Contractor's Certification:
This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.
Name JOHN MEEKER WELL DRILLING (Person, firm or corporation) (Type or print)
Address 2902 Portland Rd, Newberg, OR 97132
[Signed] John H Meeker (Water Well Contractor)
Contractor's License No. 111 Date July 10, 1977

(USE ADDITIONAL SHEETS IF NECESSARY)

SP*45656-119