

(1) OWNER: STATE ENGINEER  
Name Trappist Abbey  
Address Lafayette, Oregon

(2) LOCATION OF WELL:  
County Yamhill Owner's number, if any—  
NE 1/4 SE 1/4 Section 30 T. 3 S R. 3 W W.M.  
Bearing and distance from section or subdivision corner

TYPE OF WORK (check):  
New Well  Deepening  Reconditioning  Abandon   
Abandonment, describe material and procedure in Item 11.

(4) PROPOSED USE (check):  
Residential  Industrial  Municipal   
Irrigation  Test Well  Other

(5) TYPE OF WELL:  
Rotary  Driven   
Cable  Jetted   
Dug  Bored

(6) CASING INSTALLED: Threaded  Welded   
" Diam. from 2 1/2 ft. to 0 ft. to 3 1/2 ft. Gage 3 1/2  
" Diam. from \_\_\_\_\_ ft. to \_\_\_\_\_ ft. Gage \_\_\_\_\_  
" Diam. from \_\_\_\_\_ ft. to \_\_\_\_\_ ft. Gage \_\_\_\_\_

(7) PERFORATIONS: Perforated?  Yes  No  
Type of perforator used \_\_\_\_\_  
SIZE of perforations in. by in.  
\_\_\_\_\_ perforations from \_\_\_\_\_ ft. to \_\_\_\_\_ ft.  
\_\_\_\_\_ perforations from \_\_\_\_\_ ft. to \_\_\_\_\_ ft.  
\_\_\_\_\_ perforations from \_\_\_\_\_ ft. to \_\_\_\_\_ ft.  
\_\_\_\_\_ perforations from \_\_\_\_\_ ft. to \_\_\_\_\_ ft.  
\_\_\_\_\_ perforations from \_\_\_\_\_ ft. to \_\_\_\_\_ ft.

(8) SCREENS: Well screen installed  Yes  No  
Manufacturer's Name \_\_\_\_\_  
Type \_\_\_\_\_ Model No. \_\_\_\_\_  
In. Slot size \_\_\_\_\_ Set from \_\_\_\_\_ ft. to \_\_\_\_\_ ft.  
Diam. Slot size \_\_\_\_\_ Set from \_\_\_\_\_ ft. to \_\_\_\_\_ ft.

CONSTRUCTION:  
Was well gravel packed?  Yes  No Size of gravel: \_\_\_\_\_  
Gravel placed from \_\_\_\_\_ ft. to \_\_\_\_\_ ft.  
Was a surface seal provided?  Yes  No To what depth? \_\_\_\_\_ ft.  
Material used in seal—  
Did any strata contain unusable water?  Yes  No  
Type of water? \_\_\_\_\_ Depth of strata \_\_\_\_\_  
Method of sealing strata off \_\_\_\_\_

(10) WATER LEVELS:  
Static level 35 ft. below land surface Date 9/29/60  
Artesian pressure 720 lbs. per square inch Date \_\_\_\_\_

Log Accepted by: \_\_\_\_\_  
[Signed] \_\_\_\_\_ Date Oct 10, 1960  
(Owner)

(11) WELL TESTS: Drawdown is amount water level is lowered below static level  
Was a pump test made?  Yes  No If yes, by whom?  
Yield: gal./min. with ft. drawdown after hrs.  
" " " "  
" " " "  
Bailer test 9 gal./min. with 105 ft. drawdown after hrs.  
Artesian flow g.p.m. Date \_\_\_\_\_  
Temperature of water \_\_\_\_\_ Was a chemical analysis made?  Yes  No

(12) WELL LOG: Diameter of well 21 inches.  
Depth drilled 160 ft. Depth of completed well 160 ft.  
Formation: Describe by color, character, size of material and structure, and show thickness of aquifers and the kind and nature of the material in each stratum penetrated, with at least one entry for each change of formation.

MATERIAL	FROM	TO
clay soil	0	6
Brown clay	6	15
blue clay	15	26
grey clay	26	30
black clay	30	31
Sandstone	31	39
grey + black shale	39	65
black shale	65	82
grey shale	x2	98
Sandstone	98	99
grey shale	99	106
grey clay	106	129
grey shale	129	131
grey sandstone	131	142
black & white sandstone		
+ black shale layers	142	156
grey shale	156	160

Work started 8/30 1960 Completed 9/28 1960

(13) PUMP:  
Manufacturer's Name \_\_\_\_\_  
Type: \_\_\_\_\_ H.P. \_\_\_\_\_

Well Driller's Statement:  
This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

NAME George Zent & Son  
(Person, firm, or corporation) (Type or print)  
Address 4305 NE 44th St  
Driller's well number \_\_\_\_\_  
[Signed] \_\_\_\_\_ (Well Driller)  
License No. 2280 Date 10/10, 1960