

NOTICE TO WATER WELL CONTRACTOR

The original and first copy of this report are to be filed with the

STATE ENGINEER, SALEM 10, OREGON within 30 days from the date of well completion.

RECEIVED JUL 10 1962 STATE ENGINEER SALEM, OREGON

WATER WELL REPORT

STATE OF OREGON (Please type or print)

YAMH 4592

State Well No. 3/3W-30J(2)

State Permit No.

(1) OWNER:

Name Trappist Abbey

Address Lafayette, Oregon

(2) LOCATION OF WELL:

County Yamhill

Driller's well number

1/4 1/4 Section 29 T. 3 S. R. 3 W. W.M.

Bearing and distance from section or subdivision corner

(3) TYPE OF WORK (check):

New Well [ ] Deepening [ ] Reconditioning [x] Abandon [ ]

(4) PROPOSED USE (check):

Domestic [x] Industrial [ ] Municipal [ ] Irrigation [ ] Test Well [ ] Other [ ]

(5) TYPE OF WELL:

Rotary [ ] Driven [ ] Cable [ ] Jetted [ ] Dug [ ] Bored [ ]

(6) CASING INSTALLED:

Threaded [ ] Welded [x]

8" Diam. from 0 ft. to 160 ft. Gage .188

(7) PERFORATIONS:

Perforated? [x] Yes [ ] No

Type of perforator used touch-out Mills type

Size of perforations in. by in.

280 perforations from 4.0 ft. to 6.0 ft.

140 perforations from 1.45 ft. to 1.55 ft.

(8) SCREENS:

Well screen installed [ ] Yes [x] No

Manufacturer's Name

Model No.

Slot size Set from ft. to ft.

Diam. Slot size Set from ft. to ft.

(9) CONSTRUCTION:

Well seal—Material used in seal

Depth of seal ft. Was a packer used? NO

Diameter of well bore to bottom of seal in.

Were any loose strata cemented off? [ ] Yes [x] No Depth

Was a drive shoe used? [ ] Yes [x] No

Was well gravel packed? [x] Yes [ ] No Size of gravel: 5/8 minus

Gravel placed from 0 ft. to 160 ft.

Did any strata contain unusable water? [ ] Yes [x] No

Type of water? Depth of strata

Method of sealing strata off

(10) WATER LEVELS:

Static level 35 ft. below land surface Date 3/21/62

Artesian pressure lbs. per square inch Date

(11) WELL TESTS:

Drawdown is amount water level is lowered below static level

Was a pump test made? [ ] Yes [x] No If yes, by whom?

Yield: gal./min. with ft. drawdown after hrs.

" " " "

" " " "

Bailer test 32 gal./min. with 24 ft. drawdown after 2 hrs.

Artesian flow g.p.m. Date

Temperature of water Was a chemical analysis made? [ ] Yes [x] No

(12) WELL LOG:

Diameter of well below casing

Depth drilled ft. Depth of completed well ft.

Formation: Describe by color, character, size of material and structure, and show thickness of aquifers and the kind and nature of the material in each stratum penetrated, with at least one entry for each change of formation.

Table with columns: MATERIAL, FROM, TO. Contains handwritten log entries: 'This well was drilled in Sept. of 1960 and is cased with 21 in od casing to 38 ft. It produced about 9 gal per min. at that time.' and 'There was some caving in the well and we were to clean it out. Some new water came in at about 52 ft. below ground surface.'

Work started 3-21- 1962. Completed 4-10 19 62

Date well drilling machine moved off of well 4-10 19 62

(13) PUMP:

Manufacturer's Name

Type: H.P.

Water Well Contractor's Certification:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

NAME George Zent And Son

(Person, firm or corporation) (Type or print)

Address 4305 N.E. 44th. St Vancouver Wn.

Drilling Machine Operator's License No.

[Signed] George Zent (Water Well Contractor)

Contractor's License No. 228 Date 4/10/62, 19