

The original and first of this report are to be filed with the

RECEIVED WATER WELL REPORT
RECEIVED
 JUN 4 - 1973
 STATE OF OREGON
 APR 11 1973
 STATE ENGINEER (please type or print)
 STATE ENGINEER
 SALEM, OREGON, not write above this line

From CARD
 45/3W-4
 YAMH
 5175

STATE ENGINEER, SALEM, OREGON 97310
 within 30 days from the date of well completion.

State Well No. 45/3W-4
 State Permit No. YAMH 5175

(1) OWNER:

Name Bill Blosser
 Address RT 2 Box 234 Dayton Ore

(2) TYPE OF WORK (check):

New Well Deepening Reconditioning Abandon
 If abandonment, describe material and procedure in Item 12.

(3) TYPE OF WELL:

Rotary Cable Dug
 Driven Jetted Bored

(4) PROPOSED USE (check):

Domestic Industrial Municipal
 Irrigation Test Well Other

(5) CASING INSTALLED:

Threaded Welded
 6" Diam. from 12 ft. to 22 ft. Gage 1/4
 " Diam. from ft. to ft. Gage
 " Diam. from ft. to ft. Gage

(6) PERFORATIONS:

Perforated? Yes No.

Type of perforator used

Size of perforations in. by in.
 perforations from ft. to ft.
 perforations from ft. to ft.
 perforations from ft. to ft.

(7) SCREENS:

Well screen installed? Yes No

Manufacturer's Name
 Type Model No.
 Diam. Slot size Set from ft. to ft.
 Diam. Slot size Set from ft. to ft.

(8) WELL TESTS:

Drawdown is amount water level is lowered below static level

Was a pump test made? Yes No If yes, by whom?
 Yield: gal./min. with ft. drawdown after hrs.
air lifted 20 GPM from " "
" 315 ft after 1 hr "
 Bailer test gal./min. with 100 ft. drawdown after hrs.
 Artesian flow g.p.m.
 Temperature of water 54 Depth artesian flow encountered ft.

(9) CONSTRUCTION:

Well seal—Material used Cement
 Well sealed from land surface to 20 ft.
 Diameter of well bore to bottom of seal 9 1/2 in.
 Diameter of well bore below seal 6 in.
 Number of sacks of cement used in well seal 5 sacks
 Number of sacks of bentonite used in well seal sacks
 Brand name of bentonite
 Number of pounds of bentonite per 100 gallons
 of water lbs./100 gals.
 Was a drive shoe used? Yes No Plugs Size: location ft.
 Did any strata contain unusable water? Yes No
 Type of water? depth of strata
 Method of sealing strata off
 Was well gravel packed? Yes No Size of gravel:
 Gravel placed from ft. to ft.

(10) LOCATION OF WELL:

County Yamhill Driller's well number
 1/4 1/4 Section T. R. W.M.
 Bearing and distance from section or subdivision corner
Sec 4 T 4 S R 3 W

(11) WATER LEVEL: Completed well.

Depth at which water was first found 280 ft.
 Static level 315 ft. below land surface. Date 4/14/73
 Artesian pressure lbs. per square inch. Date

(12) WELL LOG:

Diameter of well below casing 6
 Depth drilled 315 ft. Depth of completed well 315 ft.

Formation: Describe color, texture, grain size and structure of materials; and show thickness and nature of each stratum and aquifer penetrated, with at least one entry for each change of formation. Report each change in position of Static Water Level and indicate principal water-bearing strata.

MATERIAL	From	To	SWL
Top Soil	0	2	
red clay	2	5	
Brown "	5	10	
Soft rocks	10	13	
Med Basalt	13	250	
Hard "	250	280	
pouris "	280	290	
Broken	290	315	

Work started 1/14 1973 Completed 4/14 1973
 Date well drilling machine moved off of well 1/14 1973

Drilling Machine Operator's Certification:

This well was constructed under my direct supervision. Materials used and information reported above are true to my best knowledge and belief.

[Signed] Harlan M. Duffner Date 4/17, 1973
 (Drilling Machine Operator)

Drilling Machine Operator's License No. 82

Water Well Contractor's Certification:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

Name Harlan Drilling Inc
 (Person, firm or corporation) (Type or print)

Address 729 N. Main Meyberg Ore

[Signed] Harlan M. Duffner
 (Water Well Contractor)

Contractor's License No. 117 Date 4/17, 1973