STATE OF OREGON WATER WELL REPORT (as required by ORS 537.765)

YAMH 5348

ECEIVED PLEASE TYPE OF PRINT IN en Who #18/8

45/3W-18ba
35 abandor—
(for official use only)

(1) OWNER:	RC19) LOGATION OF WELL by legal description:
Name City of Lafayette Well #1 SALEM O	PEGOM Yamhill NE% NW% of Section 7 of
Address Henderson Property	Township 4S , Range 3W , WM.
City Lafayette, State One	(Township is North or South) (Range is East or West)
(2) TYPE OF WORK (check):	MAILING ADDRESS OF WELL (or nearest address te. 2 Box 144
New Well ☐ Deepening ☐ Reconditioning ☐ Abandon ☐	Dayton. Or.
If abandonment, describe material and procedure in Item 12.	
(3) TYPE OF WELL: (4) PROPOSED USE (check):	(11) WATER LEVEL of COMPLETED WELL:
Rotary Air 🏗 Driven 🗆 Domestic 🗆 Industrial 🗀 Municipal 🍱	Depth at which water was first found ft.
Rotary Mud Dug Irrigation Withdrawal Reinjection	Static level ft. below land surface. Date
Other: Piezometric Grounding Test	Artesian pressure lbs. per square inch. Date
(E) CACING INCOMALLED	(12) WELL LOG: Diameter of well below casing
(5) CASING INSTALLED: Steel Plastic Threaded Welded	Depth drilled ft. Depth of completed well ft.
10" Diam. from	Formation: Describe color, texture, grain size and structure of materials; and show thickness and nature of each stratum and aquifer penetrated, with at least one entry for each change of
"Diam. fromft. toft. Gauge	formation. Report each change in position of Static Water Level and indicate principal
LINER INSTALLED: Steel	water-bearing strata.
Threaded	MATERIAL From To SWL
	Well was abonded because of particles in
(6) PERFORATIONS: Perforated? □ Yes □ No	water which could not be corrected. Casing
Size of perforations in. by in.	and liner left in place. Comen grout was
perforations from	introduced from bottom upward 7 liner
perforations from	was ripped with mills knife it entirety.
perforations from ft. to ft.	Amount of sealing material amounted to 32 yards of cement grout.
(7) SCREENS: Well screen installed? X Yes No	Astron or cement Stone.
Manufacturer's Name Johnson	1
Type Stainless Steel Model No.	
Diam. 6 Slot Size 010 Set from 185 ft. to 215 ft.	
Diam. Slot Size Set from ft. to ft.	3
Development	
(8) WELL TESTS: Drawdown is amount water level is lowered below static level	
Was a pump test made? Yes X No If yes, by whom?	
gal./min. with ft. drawdown after hrs.	<u> </u>
" " "	
Air test 80 gal./min. with drill stem at 180 ft. 10 hrs.	
Bailer test gal./min. with ft. drawdown after hrs.	
Artesian flow g.p.m.	
perature of water 54 Depth artesian flow encounteredft.	
(9) CONSTRUCTION: Special standards: Yes \(\subseteq \) No \(\subseteq \)	Date work started Jan. 3, 1985 /completed Jan. 4, 1985
Well seal—Material used Previosly installed	Date well drilling machine moved off of well 19
Well sealed from land surface to Sept. 29-0ct.28, 1983	(unbonded) Water Well Constructor Certification (if applicable):
Diameter of well bore to bottom of seal in,	This well was constructed under my direct supervision. Materials used and
Diameter of well bore below seal in.	information reported above are true to my best knowledge and belief.
Amount of sealing material sacks D pounds D	[Signed]
How was cement grout placed?	(bonded) Water Well Constructor Certification:
	Bond 28046279 Issued by Western Suretv
	(number) (Surety Company Name)
Was pump installed?Pulled affive re-inHtalledDepth new ft.	On behalf of Randall II. Wilcox (type or print name of Water Well Constructor)
Was a drive shoe used?	
Did any strata contain unusable water? Yes No Type of Water? depth of strata	This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belight.
Method of sealing strata off	Daniel III A Willed
	(Signed) (Water Well Constructor)
Was well gravel packed?	(Dated)
- 1b.	-