

NOTICE TO WATER WELL CONTRACTOR  
 The original and first copy of this report are to be filed with the  
 STATE ENGINEER, SALEM, OREGON 97310  
 within 30 days from the date of well completion.

**RECEIVED**  
 NOV 15 1965  
 STATE ENGINEER  
 SALEM OREGON

**WATER WELL REPORT**  
 STATE OF OREGON  
 (Please type or print)

YAMH  
5367

19H  
 State Well No. 4/3w-22  
 State Permit No. \_\_\_\_\_  
 G 3344

(1) OWNER:  
 Name Lam Sweeney  
 Address Rt 2 Box 23 Dayton

(2) LOCATION OF WELL:  
 County Yamhill Driller's well number 30  
1/4 Section 20 T. 45 R. 3W W.M.  
 Bearing and distance from section or subdivision corner \_\_\_\_\_

(3) TYPE OF WORK (check):  
 Well  Deepening  Reconditioning  Abandon   
 If abandonment, describe material and procedure in Item 12.

(4) PROPOSED USE (check):  
 Domestic  Industrial  Municipal  Irrigation  Test Well  Other   
 (5) TYPE OF WELL:  
 Rotary  Driven  Cable  Jetted  Dug  Bored

(6) CASING INSTALLED:  
 Threaded  Welded   
10" Diam. from 0 ft. to 137 ft. Gage 1/4"  
 \_\_\_\_\_" Diam. from \_\_\_\_\_ ft. to \_\_\_\_\_ ft. Gage \_\_\_\_\_  
 \_\_\_\_\_" Diam. from \_\_\_\_\_ ft. to \_\_\_\_\_ ft. Gage \_\_\_\_\_

(7) PERFORATIONS:  
 Perforated?  Yes  No  
 Type of perforator used Torch  
 Size of perforations 1/4 in. by 6 in.  
250 perforations from 40 ft. to 137 ft.  
 \_\_\_\_\_ perforations from \_\_\_\_\_ ft. to \_\_\_\_\_ ft.  
 \_\_\_\_\_ perforations from \_\_\_\_\_ ft. to \_\_\_\_\_ ft.  
 \_\_\_\_\_ perforations from \_\_\_\_\_ ft. to \_\_\_\_\_ ft.

(8) SCREENS:  
 Well screen installed?  Yes  No  
 Manufacturer's Name \_\_\_\_\_ Model No. \_\_\_\_\_  
 Diam. \_\_\_\_\_ Slot size \_\_\_\_\_ Set from \_\_\_\_\_ ft. to \_\_\_\_\_ ft.  
 Diam. \_\_\_\_\_ Slot size \_\_\_\_\_ Set from \_\_\_\_\_ ft. to \_\_\_\_\_ ft.

(9) CONSTRUCTION:  
 Well seal—Material used in seal Cement Grout  
 Depth of seal 18 ft. Was a packer used? Yes  
 Diameter of well bore to bottom of seal 16 in.  
 Were any loose strata cemented off?  Yes  No Depth \_\_\_\_\_  
 Was a drive shoe used?  Yes  No  
 Was well gravel packed?  Yes  No Size of gravel: 3/4"  
 Gravel placed from 18 ft. to 137 ft.  
 Did any strata contain unusable water?  Yes  No  
 Type of water? \_\_\_\_\_ depth of strata \_\_\_\_\_  
 Method of sealing strata off \_\_\_\_\_

(10) WATER LEVELS:  
 Static level 40 ft. below land surface Date 11-1-65  
 Artesian pressure \_\_\_\_\_ lbs. per square inch Date \_\_\_\_\_

(11) WELL TESTS: Drawdown is amount water level is lowered below static level  
 Was a pump test made?  Yes  No If yes, by whom? Driller  
 Yield: 500 gal./min. with 40 ft. drawdown after 45 hrs.  
 " " " "  
 " " " "  
 Bailer test gal./min. with ft. drawdown after hrs.  
 Artesian flow g.p.m. Date  
 Temperature of water Was a chemical analysis made?  Yes  No

(12) WELL LOG: Diameter of well below casing 0  
 Depth drilled 137 ft. Depth of completed well 137 ft.  
 Formation: Describe by color, character, size of material and structure, and show thickness of aquifers and the kind and nature of the material in each stratum penetrated, with at least one entry for each change of formation.

MATERIAL	FROM	TO
TOP SOIL	0	1
Brown Clay	1	23
Blue Clay	23	50
Black Sand	50	60
Blue Clay	60	96
Sand	96	120
Sand & Gravel	120	135
Blue Clay	135	137

Work started 10-1-65 Completed 11-1-65  
 Date well drilling machine moved off of well 11-1-65

(13) PUMP:  
 Manufacturer's Name \_\_\_\_\_  
 Type: \_\_\_\_\_ H.P. \_\_\_\_\_

Water Well Contractor's Certification:  
 This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.  
 NAME Blue Water Drilling Co.  
 (Person, firm or corporation) (Type or print)  
 Address RT 1 Box 75 Dayton, Ore  
 Drilling Machine Operator's License No. 337  
 [Signed] Robert S. Hubbard  
 (Water Well Contractor)  
 Contractor's License No. 337 Date 11-6-65