

NOTICE TO WATER WELL CONTRACTOR
The original and first copy of this report
are to be filed with the

WATER RESOURCES DEPARTMENT,
SALEM, OREGON 97310
within 30 days from the date
of well completion.

WATER WELL REPORT

STATE OF OREGON
(Please type or print)

(Do not write above this line)

YAMH
5370

State Well No. *45/3w-1999*
State Permit No.

(1) OWNER:

Name *Louis Scavini*
Address *Rt 1 Bx 12 N
Dayton, OR 97114*

(2) TYPE OF WORK (check):

New Well Deepening Reconditioning Abandon
If abandonment, describe material and procedure in Item 12.

(3) TYPE OF WELL:

Rotary Driven
Cable Jetted
 Bored

(4) PROPOSED USE (check):

Domestic Industrial Municipal
Irrigation Test Well Other

(5) CASING INSTALLED:

Threaded Welded
6" Diam. from *+2* ft. to *105* ft. Gage *250*
" Diam. from ft. to ft. Gage
" Diam. from ft. to ft. Gage

(6) PERFORATIONS:

Perforated? Yes No

Type of perforator used

Size of perforations in. by in.
perforations from ft. to ft.
perforations from ft. to ft.
perforations from ft. to ft.

(7) SCREENS:

Well screen installed? Yes No

Manufacturer's Name *JOHNSON*
Type *stainless* Model No.
Diam. *6.75* Slot size *0.80* Set from *110* ft. to *115* ft.
Diam. *6.75* Slot size *1.00* Set from *115* ft. to *120* ft.

(8) WELL TESTS:

Drawdown is amount water level is lowered below static level

Was a pump test made? Yes No If yes, by whom?
" : gal./min. with " ft. drawdown after " hrs.
" " " " " " " " " " " " " "
" *air* test *80* gal./min. with *87* ft. drawdown after *5* hrs.
" artesian flow g.p.m.
Temperature of water Depth artesian flow encountered ft.

(9) CONSTRUCTION:

Well seal—Material used *Cement Grout*
Well sealed from land surface to *18* ft.
Diameter of well bore to bottom of seal *10* in.
Diameter of well bore below seal *6* in.
Number of sacks of cement used in well seal *9* sacks
How was cement grout placed? *Pumped to bottom of annulus*

Was a drive shoe used? Yes No Plugs Size: location ft.

Did any strata contain unusable water? Yes No

Type of water? depth of strata

Method of sealing strata off

Was well gravel packed? Yes No Size of gravel:

Gravel placed from ft. to ft.

(10) LOCATION OF WELL:

County *Yamhill* Driller's well number
NE 1/4 NE 1/4 Section 19 T.4S R.3W W.M.
Bearing and distance from section or subdivision corner

(11) WATER LEVEL: Completed well.

Depth at which water was first found *111* ft.
Static level *35* ft. below land surface. Date *10-10-79*
Artesian pressure lbs. per square inch. Date

(12) WELL LOG:

Diameter of well below casing *6*
Depth drilled *140* ft. Depth of completed well *122* ft.

Formation: Describe color, texture, grain size and structure of materials; and show thickness and nature of each stratum and aquifer penetrated, with at least one entry for each change of formation. Report each change in position of Static Water Level and indicate principal water-bearing strata.

MATERIAL	From	To	SWL
<i>Top Soil</i>	<i>0</i>	<i>3</i>	
<i>Brown Clay</i>	<i>3</i>	<i>34</i>	
<i>Grey Clay</i>	<i>34</i>	<i>71</i>	
<i>Sandy Blue Clay</i>	<i>71</i>	<i>88</i>	
<i>Black Sand</i>	<i>88</i>	<i>94</i>	
<i>Sandy Grey Clay</i>	<i>94</i>	<i>111</i>	
<i>Sand & Small Gravel</i>	<i>111</i>	<i>121</i>	
<i>Blue Clay</i>	<i>121</i>	<i>140</i>	

RECEIVED

NOV - 7 1979

WATER RESOURCES DEPT
SALEM, OREGON

Work started *10-5* 1979 Completed *10-10* 1979

Date well drilling machine moved off of well *10-10* 1979

Drilling Machine Operator's Certification:

This well was constructed under my direct supervision. Materials used and information reported above are true to my best knowledge and belief.

[Signed] *Kath M Palmer* Date *10-17*, 1979
(Drilling Machine Operator)

Drilling Machine Operator's License No. *1330*

Water Well Contractor's Certification:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

Name *AQUA-TECH Well Construction Inc.*
(Person, firm or corporation) (Type or print)

Address *868 Delta Dr. N.E. Salem*

[Signed] *David Beach*
(Water Well Contractor)

Contractor's License No. *696* Date *11/1*, 1979